



# Keeping Ground Source Heat Pump Projects on the Table

**Ed Lohrenz**, B.E.S., CGD

204.318.2156

[ed@geoptimize.ca](mailto:ed@geoptimize.ca)



**Duluth, MN**

February 20-22, 2017

**GEO**optimize.ca

In accordance with the Department of Labor and Industry's statute 326.0981, Subd. 11,

“This educational offering is recognized by the Minnesota Department of Labor and Industry as satisfying **1.5 hours** of credit toward **Building Officials and Residential Contractors** continuing education requirements.”


For additional continuing education approvals, please see your credit tracking card.

# Feasibility assessments for GSHP systems

- **High percentage of potential GSHP projects scrapped at feasibility study stage. Rules of thumb are used to:**
  - Building peak loads are estimated – 400 ft<sup>2</sup> per ton or 20 Btu/hr per ft<sup>2</sup>
  - Estimate amount of drilling required – 200' of borehole per ton
  - Land area required is based on 20' spacing between boreholes
  - GHX configuration is not considered
  - Accurate hourly energy models are seldom developed at feasibility stage and are seldom used to influence building heating and cooling loads
- **This results in a GSHP system that does not provide a good return on investment and potential GSHP project is discarded as too expensive**
- **Presentation reviews one project in Minnesota that was pulled back into consideration – a 24,000 ft<sup>2</sup> new library building**

## Preliminary “feasibility assessment”

- 24,000 square feet / 400 = 60 tons capacity required
- 60 tons X 200' = 12,000' of borehole
- 12,000' X \$18 = \$216,000
- Geothermal vault = \$40,000
- **Total extra cost of GSHP system = \$256,000**






# Preliminary energy model

*Preliminary* energy model developed using Trane Trace 700 software created by ABC Engineering. Minor changes were made to the systems described in the model to allow it to run. Hourly loads converted to monthly energy loads (kBtu) and monthly peak loads (kBtu/hr)

Energy Model as Provided				
Month	Geo Cooling		Geo Heating	
	kBtu	kBtu/hr	kBtu	kBtu/hr
Jan	416	29	56198	310
Feb	2926	88	43909	310
Mar	6093	192	30052	310
Apr	18365	251	5516	236
May	30564	284	1796	215
Jun	52232	389	228	85
Jul	81898	438	0	0
Aug	82856	424	58	34
Sep	44956	440	1013	100
Oct	9619	293	9132	252
Nov	4532	89	19641	283
Dec	1205	48	39172	310
Annual	<b>335,661</b>	<b>440</b>	<b>206,716</b>	<b>310</b>
	Tons	37	Tons	26
	EFLH	763	EFLH	668



Peak cooling  
 Peak heating  
 Monthly cooling  
 Monthly heating

# Occupancy schedule in energy model


Building occupancy schedules reviewed to reflect building use as accurately as possible. Current Library Director consulted to provide estimated occupancy schedule for the proposed building. Schedule input to energy model.

		September to May								June to August							
Max	320	Mon - Thurs		Fri		Sat		Sun		Mon - Thurs		Fri		Sat		Sun	
Start Time	End Time	%	#	%	#	%	#	%	#	%	#	%	#	%	#	%	#
0	1	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0
1	2	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0
2	3	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0
3	4	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0
4	5	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0
5	6	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0
6	7	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0
7	8	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0
8	9	1%	3	1%	3	1%	3	0%	0	1%	3	1%	3	1%	3	0%	0
9	10	5%	16	5%	16	5%	16	0%	0	5%	16	5%	16	5%	16	0%	0
10	11	10%	32	10%	32	10%	32	0%	0	10%	32	10%	32	10%	32	0%	0
11	12	15%	48	20%	64	12%	38	0%	0	20%	64	20%	64	12%	38	0%	0
12	13	12%	38	15%	48	14%	45	0%	0	15%	48	15%	48	14%	45	0%	0
13	14	10%	32	12%	38	16%	51	0%	0	12%	38	12%	38	16%	51	0%	0
14	15	10%	32	10%	32	14%	45	0%	0	10%	32	10%	32	14%	45	0%	0
15	16	12%	38	15%	48	12%	38	0%	0	15%	48	15%	48	12%	38	0%	0
16	17	15%	48	20%	64	0%	1	0%	0	20%	64	20%	64	0%	1	0%	0
17	18	18%	58	25%	80	0%	0	0%	0	25%	80	25%	80	0%	0	0%	0
18	19	15%	48	1%	3	0%	0	0%	0	15%	48	1%	3	0%	0	0%	0
19	20	10%	32	0%	0	0%	0	0%	0	12%	38	0%	0	0%	0	0%	0
20	21	1%	3	0%	0	0%	0	0%	0	8%	26	0%	0	0%	0	0%	0
21	22	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0
22	23	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0
23	24	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0	0%	0

# Energy model changes to match design narrative - 15°F setback

Energy model adjusted to match design narrative as closely as possible. Design narrative includes 15°F night setback for heating and cooling from daytime setpoint.

Model Adjusted to Match Narrative - 15° Setback				
Month	Geo Cooling		Geo Heating	
	kBtu	kBtu/hr	kBtu	kBtu/hr
Jan	4155	43	51214	484
Feb	6248	113	39271	448
Mar	12127	263	26095	474
Apr	26543	371	3939	288
May	40149	451	1066	252
Jun	63092	667	29	29
Jul	92197	667	0	0
Aug	95980	667	0	0
Sep	54203	667	431	96
Oct	18253	346	7081	313
Nov	10278	125	15067	405
Dec	5544	69	34659	507
Annual	<b>428,768</b>	<b>667</b>	<b>178,852</b>	<b>507</b>
	Tons	56	Tons	42
	EFLH	643	EFLH	353






# Night setback reduced to 5°F

Night setback adjusted to 5°F. Peak cooling load drops from 667 to 625 kBtu/hr and peak heating load drops from 507 to 450 kBtu/hr.


Model Adjusted to Match Narrative - 5° Setback				
Month	Geo Cooling		Geo Heating	
	kBtu	kBtu/hr	kBtu	kBtu/hr
Jan	4569	41	53926	450
Feb	6935	113	41942	392
Mar	12710	259	28063	424
Apr	27485	369	4990	234
May	41345	395	1229	171
Jun	64436	584	39	13
Jul	94593	624	0	0
Aug	97517	625	0	0
Sep	56003	607	572	42
Oct	18736	346	8315	249
Nov	10942	125	17173	326
Dec	6054	69	38211	417
Annual	<b>441,324</b>	<b>625</b>	<b>194,460</b>	<b>450</b>
	Tons	52	Tons	37
	EFLH	706	EFLH	432



# Economizer added to heat recovery ventilation system

Economizer dampers added to heat recovery ventilation system to take advantage of cool outdoor air to provide cooling when possible. Peak cooling & monthly energy loads reduced in winter and shoulder seasons.


Addition of Economizer to Ventilation Air				
Month	Geo Cooling		Geo Heating	
	kBtu	kBtu/hr	kBtu	kBtu/hr
Jan	1388	22	53926	450
Feb	2594	63	41942	392
Mar	8627	232	28063	424
Apr	25037	369	4990	234
May	39640	395	1229	171
Jun	63482	584	39	13
Jul	94499	624	0	0
Aug	97462	625	0	0
Sep	54938	607	572	42
Oct	16393	346	8315	249
Nov	7589	99	17173	326
Dec	2846	41	38211	417
Annual	414,495	625	194,459	450
	Tons	52	Tons	37
	EFLH	663	EFLH	432



# Lighting intensity reduced and CO2 sensors added to fresh air supply

Reducing lighting intensity reduced using occupancy sensors and daylighting sensors reduces annual energy consumption from lighting (but doesn't reduce peak gains). CO2 sensors used to control fresh air supply to facility reduces heating and cooling energy loads. NOTE that reduced lighting gains *increases* heat required from GCHP system.


Lighting Intensity Reduced				
Month	Geo Cooling		Geo Heating	
	kBtu	kBtu/hr	kBtu	kBtu/hr
Jan	1275	22	59212	455
Feb	2434	61	46633	405
Mar	7437	198	32107	429
Apr	21683	306	6390	244
May	34720	358	1678	188
Jun	57393	587	49	13
Jul	88349	627	0	0
Aug	91023	628	0	0
Sep	49366	602	658	46
Oct	14060	327	10751	262
Nov	6633	93	21079	341
Dec	2505	38	43174	420
Annual	<b>376,879</b>	<b>628</b>	<b>221,730</b>	<b>455</b>
	Tons	52	Tons	38
	EFLH	600	EFLH	487



# Night setback eliminated in energy model


Warming or cooling a building to reach daytime setpoints forces full heat pump capacity for an extended time, especially to help mass in building to regain temperature. This greatly increases peak heat extraction from and heat rejection to the GHX during morning recovery period.

Night Setback Eliminated				
Month	Geo Cooling		Geo Heating	
	kBtu	kBtu/hr	kBtu	kBtu/hr
Jan	1191	22	57760	307
Feb	2515	61	45430	219
Mar	7956	199	31817	222
Apr	23359	306	8401	53
May	37031	337	2467	50
Jun	59677	466	485	16
Jul	91371	489	28	8
Aug	93328	522	77	10
Sep	52033	506	1387	22
Oct	14836	327	12125	74
Nov	7236	93	21661	99
Dec	2556	40	43202	178
Annual	<b>393,088</b>	<b>522</b>	<b>224,840</b>	<b>307</b>
	Tons	44	Tons	26
	EFLH	753	EFLH	733





# Impact of night setback on design day heating load profile

Heating the building after allowing the temperature to drop creates a peak heating requirement...and peak heat extraction from the GHX for several hours. Overnight energy loads increased to maintain temperature, but overall effect on energy cost is not large.




# Impact of night setback on design day heating load profile

Heating the building after allowing the temperature to drop creates a peak heating requirement...and peak heat extraction from the GHX for several hours. Overnight energy loads increased to maintain temperature, but overall effect on energy cost is not large.





# Impact of night setback on design day cooling load profile

Cooling the building to reach setpoint when the building is occupied in the morning significantly increases peak heat rejection to the GHX. Note that the load profiles only indicate the building loads...compressor loads add approximately 20% more heat to the GHX.



# Impact of night setback on design day cooling load profile


Cooling the building to reach setpoint when the building is occupied in the morning significantly increases peak heat rejection to the GHX. Note that the load profiles only indicate the building loads...compressor loads add approximately 20% more heat to the GHX.






# Energy model iterations

Each iteration of the energy model was changed in an attempt to reduce the peak or annual cooling loads and balance energy loads to the GHX.



# Impact of energy model iterations on GHX size


GHX modeling software was used to calculate the size of GHX required for this project based on the successive energy models. Two commonly used GHX modeling algorithms were used to determine the total amount of borehole. For larger commercial projects the G-function algorithms are considered more accurate.



Final energy model used to refine GHX layout and borehole configuration


# Changes to GHX layout and borehole configuration affect borehole length

The final iteration of the energy model was used to refine the GHX layout and borehole configuration to further reduce the total amount of borehole required. Note that allowing less efficient heat pump equipment on a cooling dominant building will *increase* the amount of drilling required.




# GHX model using hourly loads

Hourly energy model loads provide greater detail in how the GHX will perform. Monitoring the GHX allows the building operator to determine if the system is operating as designed and helps validate the design process.



## GHX model using hourly loads

Hourly energy model loads provides more detailed information to calculate the GHX more accurately. Final design is typically based on information from test borehole log, results from thermal conductivity test, estimated construction cost (based on discussions with local drilling contractors) and land area constraints.




# Geological information

Local water well logs and discussions with GHX drilling contractors indicated that a borehole depth of 200' to 275' would be the most cost-effective depth for this project. Tables were used to estimate thermal properties of the soil based on the drill logs to calculate the borehole required.

Well Name		Township Range Dir Section Subsection: Elevation		1182 ft.	Well Depth	Depth Completed	Date Well Completed		
132 43 W 3 BABDA Elevation Method		7.5 minute topographic map (+/- 5 feet)		257 ft.	257 ft.	04/30/1971			
Drilling Method --									
Well Address				Drilling Fluid					
MN				--					
				Well Hydrofractured? <input type="checkbox"/> Yes <input type="checkbox"/> No					
				From Ft. to Ft.					
Use Monitor well									
Geological Material		Color	Hardness	From To	Casing Type			Joint No Information	Drive Shoe? <input type="checkbox"/> Yes <input type="checkbox"/> No
FILL & SAND & BOULDERS				0 15	No Above/Below ft.				
SAND & BOULDERS		BROWN		15 20	Casing Diameter		Weight	Hole Diameter	
CLAY & SAND STREAKS		BLUE		20 26	Open Hole from ft. to ft.				
CLAY WITH BOULDERS		BLUE		26 35	Screen Make Type				
CLAY & SAND STREAKS		BLUE		35 44	Diameter Slot/Gauze Length Set Between				
MED. SAND & COARSE GRAVEL		BROWN		44 50					
CLAY WITH MED. FINE SAND STREAKS		GRAY		50 70					
CLAY WITH BOULDERS		GRAY		70 74					
CLAY		GRAY	HARD	74 93					
SANDY CLAY WITH BOULDERS		YELLOW		93 130					
FINE SILTY SAND CLAY STREAKS				130 198					
SANDY CLAY		BLUE		198 209					
SANDY CLAY WITH BOULDERS				209 211	Static Water Level				
SAND WITH CLAY STREAKS				211 215	ft. from Date Measured				
COARSE SAND & LOOSE GRAVEL				215 227	PUMPING LEVEL (below land surface)				
CLAY		GRAY	HARD	227 230	ft. after hrs. pumping g.p.m.				
CLAY WITH GRAVEL STREAK		GRAY		230 235	Well Head Completion				
CLAY WITH BOULDERS		GRAY		235 237	Pitless adapter manufacturer Model				
SAND WITH CLAY STREAKS				237 240	<input type="checkbox"/> Casing Protection <input type="checkbox"/> 12 in. above grade				
CLAY		GRAY		240 257	<input type="checkbox"/> At-grade (Environmental Wells and Borings ONLY)				


# Preliminary GHX layout on site

Hourly energy model loads provides more detailed information to calculate the GHX more accurately. Final design is typically based on information from test borehole log, results from thermal conductivity test, estimated construction cost (based on discussions with local drilling contractors) and land area constraints.



# From feasibility to design & implementation

The initial report estimated the approximate cost of installing a GSHP system in the Library. Soil properties were estimated, an hourly energy model was created, and a GHX model was created based on the initial findings. The estimated cost of installing a GHX was \$105,000. The next step is detailed design and implementation.





# Initial & updated energy load profile

Several iterations of an hourly energy model were developed to determine the feasibility of installing a GSHP system. As building plans finalized, building occupancy schedules were refined and mechanical system designs were developed, initial energy model was updated based on most recent information.


Night Setback Eliminated				
Month	Geo Cooling		Geo Heating	
	kBtu	kBtu/hr	kBtu	kBtu/hr
Jan	1191	22	57760	307
Feb	2515	61	45430	219
Mar	7956	199	31817	222
Apr	23359	306	8401	53
May	37031	337	2467	50
Jun	59677	466	485	16
Jul	91371	489	28	8
Aug	93328	522	77	10
Sep	52033	506	1387	22
Oct	14836	327	12125	74
Nov	7236	93	21661	99
Dec	2556	40	43202	178
Annual	<b>393,088</b>	<b>522</b>	<b>224,840</b>	<b>307</b>
	Tons	44	Tons	26
	EFLH	753	EFLH	733

Library - Loads Revised 2016-02-01				
	Geo Cooling		Geo Heating	
	kBtu	kBtu/hr	kBtu	kBtu/hr
Jan	2944	76	92228	498
Feb	6618	121	74103	442
Mar	9465	208	55901	428
Apr	19538	315	16613	364
May	31168	392	7856	356
Jun	56369	544	825	205
Jul	90300	600	14	5
Aug	93134	592	73	42
Sep	45318	560	3579	286
Oct	12517	333	28559	412
Nov	8985	128	45079	445
Dec	4250	87	74467	473
	<b>380,606</b>	<b>600</b>	<b>399,297</b>	<b>498</b>
	Tons	50	Tons	41
	EFLH	634	EFLH	802

Keeping GSHP projects on the table

# Initial & updated energy load profile


Graphic representation of building energy load profile. Cooling loads show a small increase, but heating loads have increased significantly. The loads are more balanced than initially estimated.



## Soil properties tested – thermal conductivity

A thermal conductivity test was completed in September, 2015. Calculated thermal conductivity is 0.971 Btu/hr \* ft \* °F. The conductivity seems reasonable based on the drilling log.

**Formation T.C. Test**



Circulating Fluid	Water
Starting Borehole Temp.	48.7° F
Avg. Volts	239.3
Avg. Amps	11.26
Avg. Power (Watts)	2695.53
Avg. Heat Injected (BTU/hour)	9197.53
Test Duration (Hours)	48
Test Period Analyzed	1.00-48.00
Slope	2.513
<b>Calculated Thermal Conductivity</b>	<b>0.971 Btu/hr-ft-°F</b>
Estimated Thermal Diffusivity	1.17 ft <sup>2</sup> /day



## Soil properties tested – thermal diffusivity

Thermal diffusivity is estimated based on the layers of clay, silt, sands and gravel found in the formation. Reviewing thermal diffusivity charts and calculating a weighted average shows a lower result: 0.74 ft<sup>2</sup> / day (used to calculate updated GHX field)

Footage		Net	Est'd Diff ft <sup>2</sup> /day	Weighted Average	Lithology Description		
Start	End					Circulating Fluid	Water
0.0	8.0	8.0	0.70	0.0187	Fill	Starting Borehole Temp.	48.7° F
8.0	15.0	7.0	0.60	0.0140	Brown Clay	Avg. Volts	239.3
15.0	40.0	25.0	0.60	0.0500	Gray Clay	Avg. Amps	11.26
40.0	50.0	10.0	0.90	0.0300	Sand	Avg. Power (Watts)	2695.53
50.0	75.0	25.0	1.00	0.0833	Gravel	Avg. Heat Injected (BTU/hour)	9197.53
75.0	95.0	20.0	0.80	0.0533	Till with Gravel	Test Duration (Hours)	48
95.0	148.0	53.0	0.70	0.1237	Till	Test Period Analyzed	1.00-48.00
148.0	156.0	8.0	0.90	0.0240	Sand	Slope	2.513
156.0	220.0	64.0	0.70	0.1493	Till		
220.0	226.0	6.0	0.90	0.0180	Sand		
226.0	300.0	74.0	0.70	0.1727	Till		
				300.0	Max depth drilled in feet	Calculated Thermal Conductivity	0.971 Btu/hr-ft-°F
				0	U-bend depth installed below grade		
				0.74	Total length weighted average, ft <sup>2</sup> /d	Estimated Thermal Diffusivity	1.17 ft <sup>2</sup> /day


# Long term performance of GHX

GHX modeling software can calculate the long term impact of unbalanced energy loads to and from the ground. Graph A is based on the energy model used in the feasibility assessment...it shows approximately an 8°F temperature increase over 10 years. Graph B shows calculations based on the updated energy model...approximately a 3°F rise over 10 years...because the loads are more balanced.



# GHX configuration

To ensure maximum performance from a GHX, flow rates in each of the boreholes should be approximately equal and high enough to ensure the flow is not laminar in some of the boreholes. The simplest method of ensuring equal flow is a reverse / return piping configuration.





## Designing the GHX to facilitate air removal

Air trapped in GHX piping can block flow through some boreholes. A flow velocity of 2 feet per second is needed through each section of the GHX piping to remove air. The chart shows the required flow rate needed to remove air from various pipe sizes used in the GHX design.

	Flow rate (gpm) required to achieve velocity of 2 feet per second		
Pipe Diameter	SDR11	SDR13.5	SDR15.5
<b>0.75"</b>	3.55	n/a	n/a
<b>1.00"</b>	<b>5.56</b>	n/a	n/a
<b>1.25"</b>	<b>8.87</b>	9.65	n/a
<b>2.00"</b>	18.16	<b>19.76</b>	20.70
<b>3.00"</b>	39.44	<b>42.93</b>	44.96

# Reducing header

In most projects U-tubes in the boreholes are connected to a header. It is impractical to install valves to facilitate the removal of air. Reducing headers are used to ensure the flow rate in each section of the header is adequate to remove the air from the system.






# U-tube pipe size in the borehole

Equipment specified for the Library requires flow rate of 150 gpm. Total borehole depth determined by test borehole depth...that in turn determines number of boreholes. Calculations run with 1.00" pipe (as per test borehole) and with 1.25" pipe. Pressure drop much lower with 1.25" and Reynolds number still high enough.

1: 1.00" U-tube piping		2: 1.25" U-tube piping	
<b>Overview</b> Calculate   BV   <b>Peak Load</b>		<b>Overview</b> Calculate   BV   <b>Peak Load</b>	
<b>Piping Materials List</b> System Summary Pumping Power Score: 2.6 ★★★★★		<b>Piping Materials List</b> System Summary Pumping Power Score: 1.2 ★★★★★	
Total Pipe Length (ft): 15804.0 Total Circuit Pipe Length (ft): 14400.0 Modules   Manifolds   Pre-Manifold: 2   1   0 Number of Circuits: 24 Includes Balancing Valves: No System Fluid Type: Propylene Glycol (17.7%) System Fluid Volume (Gallons): 1199.7		Total Pipe Length (ft): 15864.0 Total Circuit Pipe Length (ft): 14400.0 Modules   Manifolds   Pre-Manifold: 2   1   0 Number of Circuits: 24 Includes Balancing Valves: No System Fluid Type: Propylene Glycol (18.3%) System Fluid Volume (Gallons): 1624.7	
<b>Operational Performance - PEAK LOAD Mode</b>		<b>Operational Performance - PEAK LOAD Mode</b>	
System Flow Rate (gpm): 150.1 System Pressure Drop (ft.hd.): 29.3 Max GHX Module Pressure Drop (ft.hd.): 28.4 Reynolds Number Range for Circuits: 4434 <--> 5322		System Flow Rate (gpm): 150.1 System Pressure Drop (ft.hd.): 13.7 Max GHX Module Pressure Drop (ft.hd.): 12.9 Reynolds Number Range for Circuits: 3548 <--> 4227	
<b>Power Performance</b> Peak Load (kBtu/Hr): 600.4 Total Circulation Pump Power (hP): 1.31		<b>Power Performance</b> Peak Load (kBtu/Hr): 600.4 Total Circulation Pump Power (hP): 0.61	
<b>Purging Performance (Fluid:Water)</b> Purging Flow Rate (gpm): 71.0 Purging Pressure Drop (ft.hd.): 23.3 Required Purge Pump Power (hP): 0.70		<b>Purging Performance (Fluid:Water)</b> Purging Flow Rate (gpm): 107.2 Purging Pressure Drop (ft.hd.): 22.3 Required Purge Pump Power (hP): 1.01	

# Integrating the test borehole

Test borehole drilled in September, 2015. 1.00" U-tube was installed in the borehole... but pressure drop is much lower using 1.25" pipe. Calculations done to determine if Reynolds number still adequate if integrated with borehole field using 1.25" pipe.



# Check Reynolds numbers

During peak heat extraction heat transfer fluid becomes denser and more viscous... potentially going to laminar flow. In laminar flow (Reynolds number < 2,300) heat transfer is diminished. Calculations show that the Reynolds numbers are adequate with the 1.00" borehole connected to nearest GHX module.

1: 1.25" U-tube piping in all boreholes					2: 1.00" Test borehole integrated with nearest GHX module 1				
Name	Pipe 1 Size	Pipe 2 Size	Pipe 1 Reyn...	Pipe 2 Reyn...	Name	Pipe 1 Size	Pipe 2 Size	Pipe 1 Reyn...	Pipe 2 Reyn...
U Circuit #01	1 1/4"	1 1/4"	4096	4096	U Circuit #01	1 1/4"	1 1/4"	4277	4277
U Circuit #02	1 1/4"	1 1/4"	4065	4065	U Circuit #02	1 1/4"	1 1/4"	4258	4258
U Circuit #03	1 1/4"	1 1/4"	4006	4006	U Circuit #03	1"	1"	2605	2605
U Circuit #04	1 1/4"	1 1/4"	4023	4023	U Circuit #04	1 1/4"	1 1/4"	4198	4198
U Circuit #05	1 1/4"	1 1/4"	4130	4130	U Circuit #05	1 1/4"	1 1/4"	4273	4273
U Circuit #06	1 1/4"	1 1/4"	4102	4102	U Circuit #06	1 1/4"	1 1/4"	4239	4239
U Circuit #07	1 1/4"	1 1/4"	4102	4102	U Circuit #07	1 1/4"	1 1/4"	4234	4234
U Circuit #08	1 1/4"	1 1/4"	4130	4130	U Circuit #08	1 1/4"	1 1/4"	4256	4256
U Circuit #09	1 1/4"	1 1/4"	4023	4023	U Circuit #09	1 1/4"	1 1/4"	4140	4140
U Circuit #10	1 1/4"	1 1/4"	4006	4006	U Circuit #10	1 1/4"	1 1/4"	4115	4115
U Circuit #11	1 1/4"	1 1/4"	4065	4065	U Circuit #11	1 1/4"	1 1/4"	4169	4169
U Circuit #12	1 1/4"	1 1/4"	4096	4096	U Circuit #12	1 1/4"	1 1/4"	4193	4193
U Circuit #01	1 1/4"	1 1/4"	3724	3724	U Circuit #01	1 1/4"	1 1/4"	3760	3760
U Circuit #02	1 1/4"	1 1/4"	3697	3697	U Circuit #02	1 1/4"	1 1/4"	3732	3732
U Circuit #03	1 1/4"	1 1/4"	3643	3643	U Circuit #03	1 1/4"	1 1/4"	3678	3678
U Circuit #04	1 1/4"	1 1/4"	3659	3659	U Circuit #04	1 1/4"	1 1/4"	3694	3694
U Circuit #05	1 1/4"	1 1/4"	3756	3756	U Circuit #05	1 1/4"	1 1/4"	3792	3792
U Circuit #06	1 1/4"	1 1/4"	3731	3731	U Circuit #06	1 1/4"	1 1/4"	3766	3766
U Circuit #07	1 1/4"	1 1/4"	3731	3731	U Circuit #07	1 1/4"	1 1/4"	3766	3766
U Circuit #08	1 1/4"	1 1/4"	3756	3756	U Circuit #08	1 1/4"	1 1/4"	3792	3792
U Circuit #09	1 1/4"	1 1/4"	3659	3659	U Circuit #09	1 1/4"	1 1/4"	3694	3694
U Circuit #10	1 1/4"	1 1/4"	3643	3643	U Circuit #10	1 1/4"	1 1/4"	3678	3678
U Circuit #11	1 1/4"	1 1/4"	3697	3697	U Circuit #11	1 1/4"	1 1/4"	3732	3732
U Circuit #12	1 1/4"	1 1/4"	3724	3724	U Circuit #12	1 1/4"	1 1/4"	3760	3760

GHX 1

GHX 2

GHX 1


GHX 2

# Location of 1.00" U-tube impacts flow rates

Supply & return runouts are longer to GHX module...reducing flow rates in U-tubes, and reducing Reynolds numbers. Reynolds number in 1.00" U-tube are close to laminar flow.

To increase flow rate to GHX module 2, balancing valves added at the manifold.

1.00" Test borehole integrated with GHX 2 – no balancing valve					1.00" Test borehole in GHX 2 Balancing valves added				
Name	Pipe 1 Size	Pipe 2 Size	Pipe 1 Reyn...	Pipe 2 Reyn...	Name	Pipe 1 Size	Pipe 2 Size	Pipe 1 Reyn...	Pipe 2 Reyn...
U Circuit #01	1 1/4"	1 1/4"	4128	4128	U Circuit #01	1 1/4"	1 1/4"	3934	3934
U Circuit #02	1 1/4"	1 1/4"	4097	4097	U Circuit #02	1 1/4"	1 1/4"	3904	3904
U Circuit #03	1 1/4"	1 1/4"	4037	4037	U Circuit #03	1 1/4"	1 1/4"	3847	3847
U Circuit #04	1 1/4"	1 1/4"	4054	4054	U Circuit #04	1 1/4"	1 1/4"	3863	3863
U Circuit #05	1 1/4"	1 1/4"	4162	4162	U Circuit #05	1 1/4"	1 1/4"	3966	3966
U Circuit #06	1 1/4"	1 1/4"	4134	4134	U Circuit #06	1 1/4"	1 1/4"	3939	3939
U Circuit #07	1 1/4"	1 1/4"	4134	4134	U Circuit #07	1 1/4"	1 1/4"	3939	3939
U Circuit #08	1 1/4"	1 1/4"	4162	4162	U Circuit #08	1 1/4"	1 1/4"	3966	3966
U Circuit #09	1 1/4"	1 1/4"	4054	4054	U Circuit #09	1 1/4"	1 1/4"	3863	3863
U Circuit #10	1 1/4"	1 1/4"	4037	4037	U Circuit #10	1 1/4"	1 1/4"	3847	3847
U Circuit #11	1 1/4"	1 1/4"	4097	4097	U Circuit #11	1 1/4"	1 1/4"	3904	3904
U Circuit #12	1 1/4"	1 1/4"	4128	4128	U Circuit #12	1 1/4"	1 1/4"	3934	3934
U Circuit #01	1 1/4"	1 1/4"	3890	3890	U Circuit #01	1 1/4"	1 1/4"	4095	4095
U Circuit #02	1 1/4"	1 1/4"	3873	3873	U Circuit #02	1 1/4"	1 1/4"	4077	4077
U Circuit #03	1"	1"	2366	2366	U Circuit #03	1"	1"	2491	2491
U Circuit #04	1 1/4"	1 1/4"	3819	3819	U Circuit #04	1 1/4"	1 1/4"	4020	4020
U Circuit #05	1 1/4"	1 1/4"	3887	3887	U Circuit #05	1 1/4"	1 1/4"	4092	4092
U Circuit #06	1 1/4"	1 1/4"	3857	3857	U Circuit #06	1 1/4"	1 1/4"	4060	4060
U Circuit #07	1 1/4"	1 1/4"	3851	3851	U Circuit #07	1 1/4"	1 1/4"	4054	4054
U Circuit #08	1 1/4"	1 1/4"	3872	3872	U Circuit #08	1 1/4"	1 1/4"	4076	4076
U Circuit #09	1 1/4"	1 1/4"	3766	3766	U Circuit #09	1 1/4"	1 1/4"	3965	3965
U Circuit #10	1 1/4"	1 1/4"	3744	3744	U Circuit #10	1 1/4"	1 1/4"	3941	3941
U Circuit #11	1 1/4"	1 1/4"	3792	3792	U Circuit #11	1 1/4"	1 1/4"	3991	3991
U Circuit #12	1 1/4"	1 1/4"	3813	3813	U Circuit #12	1 1/4"	1 1/4"	4014	4014



tem. Runout pipe size,  
 fluid specifications, flow  
 ove air from the system and

# Borehole design details

Borehole design details and QA/QC program is critical to the performance of the GHX. Because the boreholes and connecting piping are buried under a parking lot it will be expensive and/or difficult to change anything after it is built.

The screenshot displays a software interface for borehole design. The left sidebar contains several sections: 'Calculations' with a 'Calculate' button and a 'Monthly' dropdown; 'Design Method' with radio buttons for 'Fixed Temperature' and 'Fixed Length' (selected), and input fields for 'Inlet Temperatures' (90.0 and 40.0) and 'Borehole Length' (300); 'Grid Layout' with a 'Use External File' checkbox, 'Borehole Number' (24), 'Rows Across' (12), 'Rows Down' (2), and 'Separation' (25.0); and 'Piping Design' with a 'Piping Builder' button. The main panel shows 'Results' for 'Fluid', 'Soil', 'U-Tube', 'Pattern', 'Extra kW', and 'Information'. Key results include: 'Calculated Borehole Equivalent Thermal Resistance' of 0.194 h\*ft\*\*°F/Btu; 'Pipe Parameters' such as 'Pipe Resistance' (0.104), 'Pipe Size' (1 1/4 in. (32 mm)), 'Outer Diameter' (1.660 in), 'Inner Diameter' (1.360 in), 'Pipe Type' (SDR11), and 'Flow Type' (Turbulent); 'U-Tube Configuration' set to 'Single'; 'Radial Pipe Placement' set to 'Average'; 'Borehole Diameter' of 4.75 in; and 'Backfill (Grout) Information' with 'Thermal Conductivity' of 1.20 Btu/(h\*ft\*\*°F).

# Grout specifications and quality control

The performance of a borehole is contingent is based on the design. If it's not built as designed it will not perform as expected. Borehole diameter, depth, pipe specifications, pipe placement, grout specifications...are all critical to performance of the system.

TG Lite / PowerTECx Mix Table								RECOMMENDED BATCH QUANTITIES		
Target TC (Btu / hr ft °F)	TG Lite (lb)	PowerTECx (lb)	Mix Water (gal)	Yield (gal)	Density (lb/gal)	% Total Solids (by weight)	% Active Solids (by weight)	TG Lite (bags)	PowerTECx (bags)	Water (gals)
0.79	50	5.0	15.5	18.1	10.2	29.8	27.9	3	1	46.5
0.88	50	7.5	16.5	19.2	10.2	29.5	26.7	2	1	33.0
1.00	50	7.5	16.0	18.7	10.2	30.1	27.3	2	1	32.0
1.07	50	10.0	18.0	20.8	10.1	28.6	25.0	3	2	54.0
1.14	50	10.0	17.5	20.3	10.1	29.1	25.5	3	2	52.5
1.20	50	10.0	16.5	19.3	10.2	30.4	26.7	3	2	49.5

Keeping GSHP projects on the table

Library GHX Details	Pipe 1 Size	Pipe 2 Size	Pipe 1 Flow Rate	Pipe 2 Flow Rate	Pipe 1 Reynold's Number	Pipe 2 Reynold's Number	Pipe 1 Pressure Drop	Pipe 2 Pressure Drop
Manifold #01 - Supply-Return Runout - Manifold 1	4"	4"	150.10 gpm	150.10 gpm	33042	33042	0.4 ft. hd	0.4 ft. hd
Manifold #01 - Pipe Section #01 - Manifold 1	4"	4"	150.10 gpm	150.10 gpm	33042	33042	0.0 ft. hd	0.0 ft. hd
GHX Module #01 - Supply-Return Runout - Module 1	3"	3"	75.82 gpm	75.82 gpm	21462	21462	0.6 ft. hd	5.5 ft. hd
Circuit #01	1 1/4"	1 1/4"	6.57 gpm	6.57 gpm	4079	4079	3.7 ft. hd	3.7 ft. hd
GHX Module #01 - Pipe Section #01	3"	1 1/4"	69.26 gpm	6.57 gpm	19603	4079	0.4 ft. hd	0.3 ft. hd
Circuit #02	1 1/4"	1 1/4"	6.53 gpm	6.53 gpm	4056	4056	3.6 ft. hd	3.6 ft. hd
GHX Module #01 - Pipe Section #02	3"	2"	62.73 gpm	13.09 gpm	17756	5686	0.4 ft. hd	0.2 ft. hd
Circuit #03	1 1/4"	1 1/4"	6.45 gpm	6.45 gpm	4005	4005	3.5 ft. hd	3.5 ft. hd
GHX Module #01 - Pipe Section #03	3"	2"	56.29 gpm	19.54 gpm	15931	8485	0.3 ft. hd	0.4 ft. hd
Circuit #04	1 1/4"	1 1/4"	6.48 gpm	6.48 gpm	4029	4029	3.5 ft. hd	3.5 ft. hd
GHX Module #01 - Pipe Section #04	3"	2"	49.80 gpm	26.02 gpm	14096	11301	0.2 ft. hd	0.6 ft. hd
Circuit #05	1 1/4"	1 1/4"	6.67 gpm	6.67 gpm	4142	4142	3.7 ft. hd	3.7 ft. hd
GHX Module #01 - Pipe Section #05	3"	3"	43.13 gpm	32.69 gpm	12209	9253	0.2 ft. hd	0.1 ft. hd
Circuit #06	1 1/4"	1 1/4"	6.63 gpm	6.63 gpm	4120	4120	3.6 ft. hd	3.6 ft. hd
GHX Module #01 - Pipe Section #06	3"	3"	36.50 gpm	39.32 gpm	10332	11129	0.1 ft. hd	0.2 ft. hd
Circuit #07	1 1/4"	1 1/4"	6.64 gpm	6.64 gpm	4126	4126	3.7 ft. hd	3.7 ft. hd
GHX Module #01 - Pipe Section #07	3"	3"	29.86 gpm	45.96 gpm	8453	13009	0.1 ft. hd	0.2 ft. hd
Circuit #08	1 1/4"	1 1/4"	6.69 gpm	6.69 gpm	4159	4159	3.7 ft. hd	3.7 ft. hd
GHX Module #01 - Pipe Section #08	2"	3"	23.17 gpm	52.65 gpm	10062	14903	0.5 ft. hd	0.3 ft. hd
Circuit #09	1 1/4"	1 1/4"	6.57 gpm	6.57 gpm	4085	4085	3.6 ft. hd	3.6 ft. hd
GHX Module #01 - Pipe Section #09	2"	3"	16.60 gpm	59.23 gpm	7207	16764	0.3 ft. hd	0.3 ft. hd
Circuit #10	1"	1"	3.23 gpm	3.23 gpm	2533	2533	2.7 ft. hd	2.7 ft. hd
GHX Module #01 - Pipe Section #10	2"	3"	13.37 gpm	62.46 gpm	5804	17678	0.2 ft. hd	0.4 ft. hd
Circuit #11	1 1/4"	1 1/4"	6.67 gpm	6.67 gpm	4143	4143	3.7 ft. hd	3.7 ft. hd
GHX Module #01 - Pipe Section #11	1 1/4"	3"	6.70 gpm	69.13 gpm	4162	19566	0.3 ft. hd	0.4 ft. hd
Circuit #12	1 1/4"	1 1/4"	6.70 gpm	6.70 gpm	4162	4162	3.8 ft. hd	3.8 ft. hd
Manifold #01 - Pipe Section #02 - Manifold 1	4"	4"	74.28 gpm	74.28 gpm	16351	16351	0.0 ft. hd	0.0 ft. hd
GHX Module #02 - Supply-Return Runout - Module 2	3"	3"	74.28 gpm	74.28 gpm	21024	21024	1.1 ft. hd	5.7 ft. hd
Circuit #01	1 1/4"	1 1/4"	6.23 gpm	6.23 gpm	3869	3869	3.4 ft. hd	3.4 ft. hd
GHX Module #02 - Pipe Section #01	3"	1 1/4"	68.05 gpm	6.23 gpm	19261	3869	0.4 ft. hd	0.3 ft. hd
Circuit #02	1 1/4"	1 1/4"	6.18 gpm	6.18 gpm	3841	3841	3.3 ft. hd	3.3 ft. hd
GHX Module #02 - Pipe Section #02	3"	2"	61.87 gpm	12.41 gpm	17511	5389	0.3 ft. hd	0.2 ft. hd
Circuit #03	1 1/4"	1 1/4"	6.09 gpm	6.09 gpm	3785	3785	3.2 ft. hd	3.2 ft. hd
GHX Module #02 - Pipe Section #03	3"	2"	55.78 gpm	18.50 gpm	15787	8034	0.3 ft. hd	0.3 ft. hd
Circuit #04	1 1/4"	1 1/4"	6.12 gpm	6.12 gpm	3801	3801	3.2 ft. hd	3.2 ft. hd
GHX Module #02 - Pipe Section #04	3"	2"	49.66 gpm	24.62 gpm	14055	10691	0.2 ft. hd	0.5 ft. hd
Circuit #05	1 1/4"	1 1/4"	6.28 gpm	6.28 gpm	3902	3902	3.3 ft. hd	3.3 ft. hd
GHX Module #02 - Pipe Section #05	3"	3"	43.38 gpm	30.90 gpm	12278	8746	0.2 ft. hd	0.1 ft. hd
Circuit #06	1 1/4"	1 1/4"	6.24 gpm	6.24 gpm	3876	3876	3.3 ft. hd	3.3 ft. hd
GHX Module #02 - Pipe Section #06	3"	3"	37.14 gpm	37.14 gpm	10512	10512	0.1 ft. hd	0.1 ft. hd
Circuit #07	1 1/4"	1 1/4"	6.24 gpm	6.24 gpm	3876	3876	3.3 ft. hd	3.3 ft. hd
GHX Module #02 - Pipe Section #07	3"	3"	30.90 gpm	43.38 gpm	8746	12277	0.1 ft. hd	0.2 ft. hd
Circuit #08	1 1/4"	1 1/4"	6.28 gpm	6.28 gpm	3902	3902	3.3 ft. hd	3.3 ft. hd
GHX Module #02 - Pipe Section #08	2"	3"	24.62 gpm	49.66 gpm	10691	14055	0.5 ft. hd	0.2 ft. hd
Circuit #09	1 1/4"	1 1/4"	6.12 gpm	6.12 gpm	3801	3801	3.2 ft. hd	3.2 ft. hd
GHX Module #02 - Pipe Section #09	2"	3"	18.50 gpm	55.77 gpm	8034	15787	0.3 ft. hd	0.3 ft. hd
Circuit #10	1 1/4"	1 1/4"	6.09 gpm	6.09 gpm	3785	3785	3.2 ft. hd	3.2 ft. hd
GHX Module #02 - Pipe Section #10	2"	3"	12.41 gpm	61.87 gpm	5389	17511	0.2 ft. hd	0.3 ft. hd
Circuit #11	1 1/4"	1 1/4"	6.18 gpm	6.18 gpm	3841	3841	3.3 ft. hd	3.3 ft. hd
GHX Module #02 - Pipe Section #11	1 1/4"	3"	6.23 gpm	68.05 gpm	3869	19261	0.3 ft. hd	0.4 ft. hd
Circuit #12	1 1/4"	1 1/4"	6.23 gpm	6.23 gpm	3869	3869	3.4 ft. hd	3.4 ft. hd

aders is important for pressure n. Because it will be buried, it's used to ensure accuracy and




Library - purging flow rate	Pipe 1 Size	Pipe 2 Size	Pipe 1 Flow Rate	Pipe 2 Flow Rate	Pipe 1 Velocity	Pipe 2 Velocity	Pipe 1 Reynold's Number	Pipe 2 Reynold's Number	Pipe 1 Pressure Drop	Pipe 2 Pressure Drop
Manifold #01 - Supply-Return Runout - Manifold 1	4"	4"	276.09 gpm	276.09 gpm	7.68 ft/s	7.68 ft/s	127247	127247	1.0 ft. hd	1.0 ft. hd
Manifold #01 - Pipe Section #01 - Manifold 1	4"	4"	276.09 gpm	276.09 gpm	7.68 ft/s	7.68 ft/s	127247	127247	0.0 ft. hd	0.0 ft. hd
GHX Module #01 - Supply-Return Runout - Module 1	3"	3"	139.32 gpm	139.32 gpm	6.40 ft/s	6.40 ft/s	82561	82561	1.5 ft. hd	13.5 ft. hd
Circuit #01	1 1/4"	1 1/4"	12.07 gpm	12.07 gpm	2.67 ft/s	2.67 ft/s	15697	15697	8.4 ft. hd	8.4 ft. hd
GHX Module #01 - Pipe Section #01	3"	1 1/4"	127.25 gpm	12.07 gpm	5.85 ft/s	2.67 ft/s	75410	15697	1.0 ft. hd	0.7 ft. hd
Circuit #02	1 1/4"	1 1/4"	11.99 gpm	11.99 gpm	2.66 ft/s	2.66 ft/s	15603	15603	8.2 ft. hd	8.2 ft. hd
GHX Module #01 - Pipe Section #02	3"	2"	115.26 gpm	24.06 gpm	5.30 ft/s	2.60 ft/s	68302	21876	0.9 ft. hd	0.4 ft. hd
Circuit #03	1 1/4"	1 1/4"	11.84 gpm	11.84 gpm	2.62 ft/s	2.62 ft/s	15401	15401	8.0 ft. hd	8.0 ft. hd
GHX Module #01 - Pipe Section #03	3"	2"	103.42 gpm	35.90 gpm	4.75 ft/s	3.88 ft/s	61286	32640	0.7 ft. hd	0.9 ft. hd
Circuit #04	1 1/4"	1 1/4"	11.91 gpm	11.91 gpm	2.64 ft/s	2.64 ft/s	15492	15492	8.1 ft. hd	8.1 ft. hd
GHX Module #01 - Pipe Section #04	3"	2"	91.51 gpm	47.81 gpm	4.21 ft/s	5.17 ft/s	54228	43468	0.6 ft. hd	1.4 ft. hd
Circuit #05	1 1/4"	1 1/4"	12.25 gpm	12.25 gpm	2.71 ft/s	2.71 ft/s	15929	15929	8.5 ft. hd	8.5 ft. hd
GHX Module #01 - Pipe Section #05	3"	3"	79.26 gpm	60.05 gpm	3.64 ft/s	2.76 ft/s	46972	35589	0.5 ft. hd	0.3 ft. hd
Circuit #06	1 1/4"	1 1/4"	12.18 gpm	12.18 gpm	2.70 ft/s	2.70 ft/s	15844	15844	8.4 ft. hd	8.4 ft. hd
GHX Module #01 - Pipe Section #06	3"	3"	67.08 gpm	72.23 gpm	3.08 ft/s	3.32 ft/s	39754	42807	0.3 ft. hd	0.4 ft. hd
Circuit #07	1 1/4"	1 1/4"	12.20 gpm	12.20 gpm	2.70 ft/s	2.70 ft/s	15865	15865	8.4 ft. hd	8.4 ft. hd
GHX Module #01 - Pipe Section #07	3"	3"	54.89 gpm	84.43 gpm	2.52 ft/s	3.88 ft/s	32527	50034	0.2 ft. hd	0.5 ft. hd
Circuit #08	1 1/4"	1 1/4"	12.29 gpm	12.29 gpm	2.72 ft/s	2.72 ft/s	15993	15993	8.6 ft. hd	8.6 ft. hd
GHX Module #01 - Pipe Section #08	2"	3"	42.59 gpm	96.72 gpm	4.61 ft/s	4.45 ft/s	38725	57320	1.2 ft. hd	0.6 ft. hd
Circuit #09	1 1/4"	1 1/4"	12.08 gpm	12.08 gpm	2.68 ft/s	2.68 ft/s	15710	15710	8.3 ft. hd	8.3 ft. hd
GHX Module #01 - Pipe Section #09	2"	3"	30.52 gpm	108.80 gpm	3.30 ft/s	5.00 ft/s	27745	64477	0.7 ft. hd	0.8 ft. hd
Circuit #10	1"	1"	5.95 gpm	5.95 gpm	2.10 ft/s	2.10 ft/s	9771	9771	8.4 ft. hd	8.4 ft. hd
GHX Module #01 - Pipe Section #10	2"	3"	24.56 gpm	114.75 gpm	2.66 ft/s	5.28 ft/s	22334	68004	0.4 ft. hd	0.9 ft. hd
Circuit #11	1 1/4"	1 1/4"	12.25 gpm	12.25 gpm	2.71 ft/s	2.71 ft/s	15940	15940	8.6 ft. hd	8.6 ft. hd
GHX Module #01 - Pipe Section #11	1 1/4"	3"	12.31 gpm	127.01 gpm	2.73 ft/s	5.84 ft/s	16015	75265	0.7 ft. hd	1.0 ft. hd
Circuit #12	1 1/4"	1 1/4"	12.31 gpm	12.31 gpm	2.73 ft/s	2.73 ft/s	16015	16015	8.7 ft. hd	8.7 ft. hd
Manifold #01 - Pipe Section #02 - Manifold 1	4"	4"	136.78 gpm	136.78 gpm	3.80 ft/s	3.80 ft/s	63038	63038	0.0 ft. hd	0.0 ft. hd
GHX Module #02 - Supply-Return Runout - Module 2	3"	3"	136.78 gpm	136.78 gpm	6.29 ft/s	6.29 ft/s	81055	81055	2.6 ft. hd	14.2 ft. hd
Circuit #01	1 1/4"	1 1/4"	11.47 gpm	11.47 gpm	2.54 ft/s	2.54 ft/s	14926	14926	7.7 ft. hd	7.7 ft. hd
GHX Module #02 - Pipe Section #01	3"	1 1/4"	125.30 gpm	11.47 gpm	5.76 ft/s	2.54 ft/s	74256	14926	1.0 ft. hd	0.6 ft. hd
Circuit #02	1 1/4"	1 1/4"	11.38 gpm	11.38 gpm	2.52 ft/s	2.52 ft/s	14810	14810	7.6 ft. hd	7.6 ft. hd
GHX Module #02 - Pipe Section #02	3"	2"	113.92 gpm	22.86 gpm	5.24 ft/s	2.47 ft/s	67509	20783	0.9 ft. hd	0.4 ft. hd
Circuit #03	1 1/4"	1 1/4"	11.22 gpm	11.22 gpm	2.48 ft/s	2.48 ft/s	14592	14592	7.3 ft. hd	7.3 ft. hd
GHX Module #02 - Pipe Section #03	3"	2"	102.70 gpm	34.08 gpm	4.72 ft/s	3.69 ft/s	60861	30982	0.7 ft. hd	0.8 ft. hd
Circuit #04	1 1/4"	1 1/4"	11.26 gpm	11.26 gpm	2.50 ft/s	2.50 ft/s	14653	14653	7.4 ft. hd	7.4 ft. hd
GHX Module #02 - Pipe Section #04	3"	2"	91.44 gpm	45.34 gpm	4.20 ft/s	4.91 ft/s	54186	41222	0.6 ft. hd	1.3 ft. hd
Circuit #05	1 1/4"	1 1/4"	11.56 gpm	11.56 gpm	2.56 ft/s	2.56 ft/s	15043	15043	7.7 ft. hd	7.7 ft. hd
GHX Module #02 - Pipe Section #05	3"	3"	79.87 gpm	56.90 gpm	3.67 ft/s	2.62 ft/s	47333	33722	0.5 ft. hd	0.3 ft. hd
Circuit #06	1 1/4"	1 1/4"	11.48 gpm	11.48 gpm	2.54 ft/s	2.54 ft/s	14940	14940	7.6 ft. hd	7.6 ft. hd
GHX Module #02 - Pipe Section #06	3"	3"	68.39 gpm	68.39 gpm	3.14 ft/s	3.14 ft/s	40527	40527	0.3 ft. hd	0.3 ft. hd
Circuit #07	1 1/4"	1 1/4"	11.48 gpm	11.48 gpm	2.54 ft/s	2.54 ft/s	14940	14940	7.6 ft. hd	7.6 ft. hd
GHX Module #02 - Pipe Section #07	3"	3"	56.90 gpm	79.87 gpm	2.62 ft/s	3.67 ft/s	33722	47333	0.3 ft. hd	0.5 ft. hd
Circuit #08	1 1/4"	1 1/4"	11.56 gpm	11.56 gpm	2.56 ft/s	2.56 ft/s	15043	15043	7.7 ft. hd	7.7 ft. hd
GHX Module #02 - Pipe Section #08	2"	3"	45.34 gpm	91.44 gpm	4.91 ft/s	4.20 ft/s	41222	54186	1.3 ft. hd	0.6 ft. hd
Circuit #09	1 1/4"	1 1/4"	11.26 gpm	11.26 gpm	2.50 ft/s	2.50 ft/s	14653	14653	7.4 ft. hd	7.4 ft. hd
GHX Module #02 - Pipe Section #09	2"	3"	34.08 gpm	102.70 gpm	3.69 ft/s	4.72 ft/s	30982	60861	0.8 ft. hd	0.7 ft. hd
Circuit #10	1 1/4"	1 1/4"	11.22 gpm	11.22 gpm	2.48 ft/s	2.48 ft/s	14592	14592	7.3 ft. hd	7.3 ft. hd
GHX Module #02 - Pipe Section #10	2"	3"	22.86 gpm	113.92 gpm	2.47 ft/s	5.24 ft/s	20783	67509	0.4 ft. hd	0.9 ft. hd
Circuit #11	1 1/4"	1 1/4"	11.38 gpm	11.38 gpm	2.52 ft/s	2.52 ft/s	14810	14810	7.6 ft. hd	7.6 ft. hd
GHX Module #02 - Pipe Section #11	1 1/4"	3"	11.47 gpm	125.30 gpm	2.54 ft/s	5.76 ft/s	14926	74256	0.6 ft. hd	1.0 ft. hd
Circuit #12	1 1/4"	1 1/4"	11.47 gpm	11.47 gpm	2.54 ft/s	2.54 ft/s	14926	14926	7.7 ft. hd	7.7 ft. hd

from system

should facilitate air


# Detailed manifold design

Specifications for the manifold and transitions from HDPE supply / return runouts to manifold and building piping system should be clear. Building penetrations should be appropriate for soil conditions.




# Flushing procedures

Design should facilitate the contractor's ability to fill, flush and purge the system as easily as possible. Flush ports and valves should be designed for flow rates required.





## Design specifications for contractor should be very clear

Specifications for contractor should be as clear as possible. Should indicate the minimum flow rates required to flush air, dirt and debris from the system...to prevent poor operation after turnover.




# Annual GHX temperature profile for building owner / operator

Building owner / operator should be provided with annual temperature profile the GHX is expected to operate at. If temperature deviates very much from expected profile, the cause should be determined. Operator should also be aware of the daily temperature range that can be expected.



# Daily GHX temperature profile

- Energy model indicates cooling load of 50 tons, heating load 408 kBtu/hr
- GHX design based on actual TC test and energy model: 7,200' of borehole
- 7,200' X \$16 = \$115,000
- Geothermal vault - not required
- **Total extra cost of GSHP system = \$115,000 (versus \$256,000)**



Fergus Falls Library - Loads Revised 2016-02-01				
	Geo Cooling		Geo Heating	
	kBtu	kBtu/hr	kBtu	kBtu/hr
Jan	2944	76	92228	498
Feb	6618	121	74103	442
Mar	9465	208	55901	428
Apr	19538	315	16613	364
May	31168	392	7856	356
Jun	56369	544	825	205
Jul	90300	600	14	5
Aug	93134	592	73	42
Sep	45318	560	3579	286
Oct	12517	333	28559	412
Nov	8985	128	45079	445
Dec	4250	87	74467	473
	<b>380,606</b>	<b>600</b>	<b>399,297</b>	<b>498</b>
	Tons	50	Tons	41
	EFLH	634	EFLH	802



# Keeping Ground Source Heat Pump Projects on the Table

**Ed Lohrenz**, B.E.S., CGD

204.318.2156

[ed@geoptimize.ca](mailto:ed@geoptimize.ca)



**Duluth, MN**

February 20-22, 2017

**GEO**optimize.ca