



Research Update:

Condensing Boiler Optimization

Duluth Energy Design Conference
2/22/2017

Rebecca Olson

Neighborhood Energy Connection



Neighborhood Energy Connection
tools for energy-efficient living



Center for Energy and Environment



This project was supported in part by a grant from the Minnesota Department of Commerce, Division of Energy Resources through the Conservation Applied Research and Development (CARD) program.



Continuing Education

In accordance with the Department of Labor and Industry's statute 326.0981, Subd. 11,

“This educational offering is recognized by the Minnesota Department of Labor and Industry as satisfying **1.5 hours** of credit toward **Building Officials and Residential Contractors** continuing education requirements.”



For additional continuing education approvals, please see your credit tracking card.



Objectives

- Understand how residential condensing boilers are being installed in MN
- Learn about HVAC contractor barriers and attitudes toward condensing boilers in residential applications
- Interpret data from monitoring of previously installed condensing boilers
- Learn which factors affect condensing boiler efficiency in single family homes
- Apply lessons learned from the research project into boiler installation practices
- Understand the overall goals of this research project
- Get updated on next steps of optimization project

Introduction to Hydronic Heating





Introduction to Hydronic Heating

- Non-condensing vs. condensing
 - Conventional boiler: condensation of combustion gases can rust out heat exchanger
 - Condensing boiler: condensation of combustion gases is optimum for efficiency
- Difference in return temperature requirement
 - In order to get combustion gases to condense, the return water temperature needs to be below $\sim 130^{\circ}$
- Radiator types
 - Radiator types and size play a significant role in the ΔT between supply and return temps.
- Issues with replacement from one to other
 - It's important to optimize efficiency when replacing a conventional boiler with a condensing boiler based on the above factors

Hydronic Heating in MN


- Approximately 30% of MN homes are heated by a boiler
- Most of these are in older cities like St. Paul and Minneapolis
- Some in northern locations where central A/C is in less demand





Condensing Boilers

- How it works:
 - 2nd condensing heat exchanger
 - Less waste heat up the chimney
 - If return water temp is low, more heat is exchanged from the combustion gases to the boiler water: increasing efficiency
 - Supply temperature, flow rates and radiator type/size dictate return water temp.





Need for Condensing Boiler Research

- Lack of modulating condensing boilers in residential market
- Evidence that HVAC contractors and utilities have inconsistent confidence in products
- Prior research showing how important return temperature is on condensing boilers—commercial and hydronic air handler studies
- Need for quality installation protocol for utility savings and cost benefit confidence



Contractor Hesitance and Cost

- Cost of condensing units is generally high and variable
 - \$6,500--\$15,000 installation cost range
- Lack of confidence in operation at high efficiency
- Issues with early models and maintenance callbacks
- Confusion about supply set-temps and condensing rate optimization
- Not as many model options in this market as condensing forced air systems



Condensing Boiler Rebates in MN


- Current rebates for condensing units are offered by:
 - Centerpoint Energy (91%+ AFUE=\$500)
 - MN Energy Resources (90%+ AFUE=\$200)
 - Great Plains Natural Gas (91%+ AFUE=\$500)
 - Greater MN Gas (90%+ AFUE=\$500)
 - New in 2017: Xcel Energy (90%=\$300, 95%+=\$400)
- 2017 Federal tax credit: TBD?



Prior Research and Information

- Conclusions:
 - Return water temp is a primary factor
 - Flow rates can influence return water temperature
 - Outdoor reset needs to be installed and set-up properly
 - Needed more info pertaining to MN housing stock, radiator types, and climate as well as more field implementation guidelines
- Building America—Butcher/Arena
- Commercial Boiler study—CEE Russ Landry
- ASHRAE Handbook

Prior Research and Information





Research Project Structure

- Field and Market research
- Existing condensing boiler monitoring
- Draft retro-commissioning activities
- Monitor savings after retro-commissioning
- Development of Quality Installation Protocol for Utility rebates based on savings from retro-commissioning
- Work with contractors to install condensing boilers in homes using QI protocol
- Information dissemination through webinars, presentations and published reports



Research Project Timeline

Task	Name	Q1	Q2	Q3	Q4	Q1	Q2	Q3	Q4	Q1	Q2	Q3	Q4
1	Assessment	█	█										
2	Existing boiler monitoring	█	█	█	█	█	█	█	█	█	█		
2.2	Existing monitoring	█	█	█	█	█	█						
2.3	recommissioning					█	█	█					
2.4	Post monitoring					█	█	█	█	█	█		
2.5	refinement of recommissioning checklist					█	█			█	█		
3	New boiler installation			█	█	█	█	█	█	█	█		
3.2	Installation					█	█						
3.3	Monitoring					█	█	█	█	█	█		
3.4	refinement of installation checklist					█	█			█	█		
4	Final report										█	█	█



Market Research Structure

- Interview HVAC contractors about installation
 - Procedures
 - Pricing
 - Barriers
 - Incidence
- Interview homeowners about performance
 - Comfort
 - Maintenance
 - Issues
- Interview Utilities about rebate development and rationale



Early Market Research Results

- **Interview HVAC contractors about installation**
 - 6 companies interviewed so far including a supplier
 - Low volume of boiler replacements and even lower volume of condensing
 - Some hesitation on cost vs. performance
 - Costs seem to be inconsistent with equipment and labor details
- **Interview homeowners about performance of existing condensing Boiler**
 - Comfort is very high in existing sites
 - Maintenance does not seem to be an issue with any of the sites
 - Most sites relied on contractor to choose model
 - All 6 residents said they would recommend condensing system to others
- **Interview Utilities about rebate development and rationale**
 - Preliminary discussion with Xcel indicates they were worried about cost effectiveness.
 - They may be getting high installation cost estimates, and not have a lot of confidence in the efficiency



Field Research Phase I

- Characterization of Typical MN households
 - Based on aggregate consumption data from existing programs
- Participant solicitation/selection
- 6 sites chosen with existing modulating condensing boilers installed within the last 5 years
- Sites have varied heating loads and construction characteristics
- All homes have cast iron radiators
 - Some have other convector types, (i.e. baseboard, in-floor, low mass)
- 3 sites have indirect water heaters
- Monitoring
 - Gas usage
 - Supply and return water temperature
 - Flow rates
 - Condensation rate



Field Research Phase I

- 1st half of 2015/2016 heating season, monitored as installed
- Made minor changes to optimize efficiency
 - Adjusted supply temp
 - Optimized turn-down ratio
 - Attempted to change DHW supply temp and flow rate
- 2nd half of 2015/2016 heating season, monitored after adjustments
- Measured savings from 1st half to 2nd half
- Developed draft quality installation protocol




Site Selection Criteria

- At least 1 home per typical heating load quartile (420 to 700, 700 to 830, 830 to 1275, and ≥ 1275 therms/yr)—based on MN aggregated residential utility program data
- At least 1 of each of the top 3 manufacturers—identified by utility rebate and local sales info
- A variety of installers
- MN program databases suggest between 30-36% of condensing boiler installs had indirect water heaters
- National Grid study found 30-40% of outdoor reset were not installed or installed poorly
- A variety of emitter types. Cast iron radiation, Low mass radiation, baseboards, and in-floor heating


Site Selection and Recruitment

- **17 recruited homes had smaller loads than typical homes (Avg 720 therm/yr)**
 - In selected 6 sites, larger usage homes were slightly under represented
- **Identified 6 different manufacturers in recruitment.**
 - Top brands based on supplier and utility rebate data are represented in 6 selected sites
 - Triangle tube, Buderus, Bunham, Weil Mclain all included
- **11 different installers in recruited homes**
 - 5 different installers in selected sites







Monitoring Set-up



Phase I Pre Retro-commissioning Daily Measured Performance



Daily Measured Performance



Phase I: As-found performance

		Annual Energy Use		Annual Efficiency		
Site	Mode	Space Heating	DHW	Combined	Space Heating	DHW
		therms/yr	therms/yr			
d215_ex_02	As-found	837	na	na	88.4%	na
d215_ex_03	As-found	536	112	88.0%	90.5%	76.1%
d215_ex_05	As-found	459	94	88.0%	91.6%	70.3%
d215_ex_06	As-found	669	na	na	95.1%	na
d215_ex_07	As-found	731	na	na	89.0%	na



Retro-Commissioning Actions

- **Lowered Supply Temperature**
 - Determined reasonable level to still meet load, but lower return temp. to optimize efficiency
- **Adjusted overall Reset Curve**
 - Maximum supply temperature output at -12° vs. default of 0°
 - This will lower the slope of the curve making more points along the curve in the condensing mode
- **Adjusted DHW Supply when possible**
 - Based on lower efficiencies of indirect tanks as well as indications of unused capacity
 - This was either impossible, or didn't actually have an effect on the return temp because of heat exchange capability

Phase I Site Example (D215_ex_07)

- Boiler for space heating only
- 6 Cast iron radiators
- 2 low mass radiators
- 3 zones w/ 3 t-stats



Capacity Estimates and Ratings (Btu/hr)		
Boiler Output	Min	Max
	28,500	99,000
Emmitters	at 140 Sup T	at 180 Sup T
	35,000	65,000
Design Heating Load (Bill Analysis)	at -12 F OAT	
	38,500	








Supply Temperature Optimization

- Calculate or estimate the home heating load
- Calculate or estimate the emitter capacity
- Minimize the supply water temperature so that the house load can still be met

Phase I Site Example (D215_ex_07)




Site Example(D215ex07)Emitter Capacity






Site Example(D215ex07) Improvement





After retro commissioning performance




As-Found Annual Efficiency: 89.0%

Optimized Reset 90.5%


Site Example (D215_ex_03) - DHW

- Boiler and indirect water heater
- 6 Cast iron radiators
- 41 Gal WH set at 130°F



Capacity Estimates and Ratings (Btu/hr)		
Boiler Output	Min	Max
	22,745	75,200
Emmiters	at 140 Sup T	at 180 Sup T
	22,234	41,997
Design Heating Load (Bill Analysis)	at -12 F OAT	
	28,925	

Site Example (D215 ex 03)








DHW Optimization

- Does the current DHW capacity meet load?
- Minimize the supply water temperature
 - Many older boilers fix the DHW temperature
 - d215_ex_03
- Minimize the DHW loop flow rate
 - Manual pump adjustment
 - Or boiler settings


Site Example (D215 ex 03)



After retro commissioning performance



	Pump Speed	DHW GPM	Return Water T	Capacity (Btu/hr)	Avg Eff
As-Found	High	2.8	133	53,100	76.1%
Opt_1	Med	2.5	131	49,300	77.3%
Opt_2	Low	2	129	45,500	77.9%



Comparison Chart

Site	Mode	Annual Combined Eff	Annual Space Eff	Annual DHW thermal Eff
d215_ex_01	As-found	82.6%	86.2%	62.6%
d215_ex_01	Opt - OAT Curve	Analysis On-going		
d215_ex_02	As-found	na	88.4%	na
d215_ex_02	Opt - OAT Curve	na	90.2%	na
d215_ex_03	As-found	88.0%	90.5%	76.1%
d215_ex_03	Opt- Clean	88.2%	90.5%	77.1%
d215_ex_03	Opt - DHW 1	88.4%	90.5%	77.3%
d215_ex_03	Opt - DHW 2	88.6%	90.5%	77.9%
d215_ex_05	As-found	88.0%	91.6%	70.3%
d215_ex_05	Opt- NA	No Optimization to be Done		
d215_ex_06	As-found	na	95.1%	na
d215_ex_06	Opt - NA	No Optimization to be Done		
d215_ex_07	As-found	na	89.0%	na
d215_ex_07	Opt - OAT Curve		90.4%	



Conclusions Optimization

- Enabling recommended OAT reset curve will achieve majority of savings
 - Further optimization is possible, but not typically cost effective
- Water heating has room for improving efficiency
 - However the system must be designed for low water temperatures (which appears to be uncommon)




Field Research, Phase II


- Selected 7 homes looking to replace non-condensing boiler with condensing boiler
- Used similar solicitation and selection criteria to Phase I
- Worked with 4 contractors to install new boiler in accordance with draft QI protocol in selected sites
- Monitoring (same as existing sites)
 - Gas usage
 - Supply and return water temperature
 - Flow rates
 - Condensation rate
- Measure efficiency and compare to Phase I to estimate potential savings associated with QI protocol

Phase II Set-up Procedure leading to QI guide


- Boiler sized according to manual J
 - Ensure minimum firing rate is as low as possible
- Ensure outdoor reset is installed and meets manufacturer specifications.
 - Ex. Not located in sunny location or in exhaust path
- Set appropriate reset curve



Comparison Chart Phase II



Comparison of Annual Space Heating Efficiency



- On average condensing boilers saved 14% annual space heating costs over 80% AFUE boilers.
- Indirect water heaters were equivalent to a 0.70 EF power vent WH



Preliminary Conclusions

- Condensing equipment meet expected savings
 - Even boilers with non-aggressive reset curves are efficient because set temp is reached before supply water temp gets to high limit
 - 1-3% savings potential based on intensive set-up procedure—emitter capacity measurement
 - Not cost effective
- DHW performance is more aligned with Power vented water heater than condensing
 - Not recommending unless cost competitive with power vent



Dissemination Plan

- Hold several webinars and live presentations about project findings
- Work with contractors involved in interviews as well as installations to adopt QI protocol and hone in on pricing
- Work with WX agencies to determine assessment protocol for condensing boiler work scope
- Work with gas utilities not currently offering rebates for mod cons to implement rebate with QI protocol required
- Publish final research report and send out with DER newsletters etc.



Future plans

- Analyze cost effectiveness
- Finalize optimized reset curve recommendations
- Communicate with utilities about Basic set-up protocol
- Get information out based on Dissemination plan
- Publish final research report and send out with DER newsletters etc.



Thank You!

Rebecca Olson

Residential Energy Program Director, Neighborhood Energy Connection

rebecca@thenec.org

651-789-5705

Project Partners:

Ben Schoenbauer

Senior Research Engineer

Center for Energy and Environment

bschoenbauer@mncee.org

612-244-2413

Dave Bohac

Director of Research

Center for Energy and Environment

dbohac@mncee.org

612-802-1697

This project was supported in part by a grant from the Minnesota Department of Commerce, Division of Energy Resources through the Conservation Applied Research and Development (CARD) program.



Neighborhood Energy Connection
tools for energy-efficient living

