

# Welcome

High Performance Mechanicals for  
Houses That Work

Energy Design Conference - Duluth, MN

February 21<sup>st</sup>, 2018



EEBA's Educational Series



EEBA



Energy & Environmental Building Alliance

# Local Sponsor



# EEBA National Education Partners



Gypsum



COOLING & HEATING



# CEU's

In accordance with the Department of Labor and Industry's statute 326.0981, Subd. 11,

“This educational offering is recognized by the Minnesota Department of Labor and Industry as satisfying **1.5 hours** of credit toward **Building Officials and Residential Contractors code /1 hour energy** continuing education requirements.”


For additional continuing education approvals, please see your credit tracking card.

1.5 EA/PER PART

- EEBA High Performance Mechanicals Part 1
- EEBA High Performance Mechanicals Part 2
- EEBA High Performance Mechanicals Part 3
- EEBA High Performance Mechanicals Part 4

# Andrew Oding EEBA Certified Trainers

[www.constructioninstruction.com](http://www.constructioninstruction.com)



# Who's Here?

6




# Topics for Discussion

- What's different in high performance homes?
- The building science connection to mechanical systems
- The right decisions in the right order for all systems
  - The right size
  - Integrated design
  - Equipment alternatives
  - Getting installation right
  - Commissioning
  - Expectation education



# How we build has changed

## How we live in homes has changed



# The original 800-1200 sq.ft starter home

**160 MBH**



**40 MBH**




# The new 800-1200 sq.ft starter home


**30 MBH**




**180 MBH**



# New Mechanical Priorities



HERs 100



HERs 50

# Tighter Buildings ..... Larger Exhausts



# Larger windows .... Opened less



# NEW CODES, NEW ZERH, NEW DESIGNS...



Irrational Enclosure Design = Irrational Mechanical

It's about finding the economical and sustainable balance between  
Passive vs Active systems (Goldilocks scenario)

Lower sensible loads ... higher % latent loads




# More lights, appliances, hot water




# Advanced systems ... higher expectations





Codes are Changing - Continual Improvement


# PAST, PRESENT AND FUTURE




**NOTE: Renewable Energy Becomes More Cost Effective**

# Energy Efficiency Scale

- Every 1 point reduction is equal to a 1% reduction in energy use






- meets or exceeds the 2015 IECC or equivalent (10)
- meets or exceeds the 2012 IECC or equivalent (10)
- meets or exceeds the 2009 IECC or equivalent (22)
- meets or exceeds the 2006 IECC or equivalent (2)
- no statewide code or precedes the 2006 IECC (12)




## Code adoption as of March, 2017

# 30 years ago....




# IECC 2015....

SMALLER TOTAL CIRCLE  
LOAD PROFILE HAS CHANGED



# NET ZERO / ZERH....




Are we ready  
for the  
changes?



# Be Aware...

- Energy Efficiency  $\neq$  Comfort
- Builders typically have more comfort complaints than high bill complaints
- If you can't provide comfort, energy efficiency could be set back 20 years
- Need to remember comfort fundamentals



# Let's Start with Defining Comfort

- Air temperature
- Humidity
- Air speed - drafts
- Surrounding surface temperatures
- Gender, age, activities of occupants
- Metabolic rate & clothing



**ANSI/ASHRAE Standard 55-2010**  
(Supersedes ANSI/ASHRAE Standard 55-2004)  
Includes ANSI/ASHRAE addenda listed in Appendix I

## **ASHRAE STANDARD**

### **Thermal Environmental Conditions for Human Occupancy**

See Appendix I for approval dates by the ASHRAE Standards Committee, the ASHRAE Board of Directors, and the American National Standards Institute.

This standard is under continuous maintenance by a Standing Standard Project Committee (SSPC) for which the Standards Committee has established a documented program for regular publication of addenda or revisions, including procedures for timely, documented, consensus action on requests for change to any part of the standard. The change submittal form, instructions, and deadlines may be obtained in electronic form from the ASHRAE Web site ([www.ashrae.org](http://www.ashrae.org)) or in paper form from the Manager of Standards. The latest edition of an ASHRAE Standard may be purchased from the ASHRAE Web site ([www.ashrae.org](http://www.ashrae.org)) or from ASHRAE Customer Service, 1791 Tullie Circle, NE, Atlanta, GA 30329-2305. E-mail: [orders@ashrae.org](mailto:orders@ashrae.org). Fax: 404-321-5478. Telephone: 404-636-8400 (worldwide), or toll free 1-800-527-4723 (for orders in US and Canada). For reprint permission, go to [www.ashrae.org/permissions](http://www.ashrae.org/permissions).

© 2010 American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc.

ISSN 1041-2336



**American Society of Heating, Refrigerating  
and Air-Conditioning Engineers, Inc.**  
1791 Tullie Circle NE, Atlanta, GA 30329  
[www.ashrae.org](http://www.ashrae.org)



# Comfort – Finding the sweet spot

## Applies to Operative Temperature

Computer model method and Section 5.2.3 for the  
Optional Method for Naturally Conditioned Spaces.

For further compliance requirements,  
see Sections 6 and 7.




Figure 2: The new Graphic Comfort Zone Method, Figure 5.2.1.1 in Standard 55-2010 (IP version shown).

# THERMAL COMFORT DEFINED: ASHRAE 55( 40 years old)


1. Air Temperature(Ambient)
2. Surrounding Surface Temperature(MRT)
3. Humidity

## PERSONAL FACTORS:

1. Air movement-Drafts(Air Speed)
2. Occupant Activity AND Sensitivity(Metabolic Rate and Clothing )

ASHRAE 55...."Mean Radiant Temperature"

<http://comfort.cbe.berkeley.edu/>



The Temperatures of the surrounding walls ,floors and windows impacts comfort MORE than air temperature(Thermostat).

How does the body lose (transfer) heat?

- 15% humidity/perspiration
- 35% convection/air movement
- **50% radiation heat exchange.**



# Operative Temperature

## Operative temperature:

- The average of the **mean radiant** and ambient air temperatures, weighted by their respective heat transfer coefficients.
- Thermostats respond to air temperature
- Human **thermal comfort** responds to operative temperature



# Can we meet the expectations of our customers?

<b>Residential Single-Zone and Multi-Zone Systems</b> Minimum / Maximum Recommended Values for Comfort and Safety		
Comfort Item	Heating Season	Cooling Season
Thermostat setpoint (design)	70°F	75°F
Relative humidity (RH) <sup>1</sup>	30% RH maximum (20 – 30% RH is desirable)	55% RH maximum (25 – 50% RH is desirable)
Dry-bulb temperature at the thermostat	Setpoint temperature ±2°F	Setpoint temperature ±3°F (single-zone) Setpoint temperature ±2°F (multi-zone)
Dry-bulb temperature in any conditioned room	Setpoint temperature ±2°F	Setpoint temperature ±3°F (single-zone) Setpoint temperature ±2°F (multi-zone)
Room-to-room temperature differences (i.e., same level)	4°F maximum	6°F maximum (single-zone) 4°F maximum (multi-zone)
Floor-to-floor temperature differences (i.e., different levels)	4°F maximum	6°F maximum (single-zone) 4°F maximum (multi-zone)
Floor temperature (slab floors or floors over unconditioned space)	65°F minimum at 4" above the floor for 70°F thermostat setting [not applicable near outside walls]	----
Air filtration – MINIMUM EFFECTIVENESS <sup>2</sup>	MERV <sup>3</sup> rating of 4 – 6 [Standard disposable media filter]	MERV <sup>3</sup> rating of 4 – 6 [Standard disposable media filter]
Air filtration – BETTER EFFECTIVENESS <sup>2</sup>	MERV <sup>3</sup> rating of 8 – 11 [1-2" residential pleated filter]	MERV <sup>3</sup> rating of 8 – 11 [1-2" residential pleated filter]
Ventilation (outdoor air introduced into the occupied space)	0.35 air changes per hour (ACH) [for any infiltration-ventilation combination]	0.35 air changes per hour (ACH) [for any infiltration-ventilation combination]
Air circulation within room <sup>4</sup>	Size and location of supply outlets selected for optimum heating performance / low resistance return path required for every room	Size and location of supply outlets selected for optimum cooling performance / low resistance return path required for every room

# Comfort – A starting point

<b>Parameter</b>	<b>Setting</b>	<b>Range</b>
<b>Temperature</b> Summer Winter	75 °F 72 °F	+/- 3 °F +/- 3 °F
<b>Humidity</b> Summer Winter	50% 35%	+/- 5% +/- 5%
<b>Foot Comfort</b>	63 °F	+/- 3 °F

# Heating & Cooling Systems

## Fuel choices


- Electric
- Gas
- Oil
- Wood
- Solar
- Combinations

## Distribution choices

- Central Forced air
- Radiant
  - In-floor
  - Baseboard
- Ductless
- Space heaters



1) Get heating  
& cooling  
capacity right



ACCA Sizing Standards



# Heat Flow Formulas

**Conduction heat flow** (through walls, ceilings, floors)

$$= (\text{Surface Area} \times \text{Temp. Diff.}) / \text{R-value}$$

**Radiant flow** (through glass)

$$= \text{Surface area} \times \text{Solar incidence} \times \text{Solar Heat Gain Coefficient}$$

**Heat flow by air** (via air leakage or ventilation) - Sensible


$$= \text{Volume of air (CFM)} \times \text{Temp. Diff.} \times 1.1$$

# HEATING – Get the Size Right

- Do Room-by-Room heat loss & gain calculation

## Based on:

- Design Day - Winter
- Conduction losses through enclosure
- Air leakage through enclosure
- Heat losses through ducts in unconditioned space



SECOND FLOOR PLAN

# Madison, WI

- design conditions

38

Condition	ASHRAE 99% / 1%
Winter, design dry bulb (F)	-9°F
Summer, design dry bulb (F)	90°F
Summer, design wet bulb (F)	74.4°F
Degree days-heating	7197
Degree days-cooling	608
Precipitation	31"
Solar incidence - South, July	100

# Lets do a one room example

## Conductive Heat Loss/ Gain

- 2 exposed walls
- One exposed ceiling
- One window


## Radiant Heat Gain (Cooling)

- Solar gain through window
- + Internal loads
- + Air leakage & ventilation

*Participants complete the example on your worksheet*

*Assume 10' high ceilings*

*Assume window SHGC = 0.3*



# HVAC Sizing

<b>Component</b>	<b>Surface area</b>	<b>x</b>	<b>Temp. Diff.</b>	<b>/</b>	<b>R-value</b>	<b>= BTUs/Hr</b>
<b>Ceiling:</b> Winter Summer	_____ sq.ft.				<b>R30</b>	
<b>Walls:</b> Winter Summer	_____ sq.ft.				<b>R15</b>	
<b>Windows:</b> Winter Summer	_____ sq.ft.				<b>R3</b>	

# HVAC Sizing

<b>Component</b>	<b>Surface area</b>	<b>x</b>	<b>Temp. Diff.</b>	<b>/</b>	<b>R-value</b>	<b>= BTUs/Hr</b>
<b>Ceiling:</b> Winter Summer	<b>150 sq.ft.</b>				<b>R30</b>	
<b>Walls:</b> Winter Summer	<b>250 sq.ft.</b>				<b>R15</b>	
<b>Windows:</b> Winter Summer	<b>20 sq.ft.</b>				<b>R3</b>	

# HVAC Sizing

Component	Surface area	x	Temp. Diff.	/	R-value	= BTUs/Hr
<b>Ceiling:</b>						
<b>Winter</b>	150 sq.ft.		60		R30	300
<b>Summer</b>			20			100
<b>Walls:</b>						
<b>Winter</b>	250 sq.ft.		60		R15	1000
<b>Summer</b>			20			333
<b>Windows:</b>						
<b>Winter</b>	20 sq.ft.		60		R3	400
<b>Summer</b>			20			133

Solar gain (South) = 20 x 100 x 0.3 SHGC = 600 BTUs/hr

Solar gain (West) = 20 x 160 x 0.3 SHGC = 960 BTUs/hr

# HVAC Sizing

Air leakage / ventilation heat loss

= CFM x temp. difference x 1.1

= 60 x 60 x 1.1 = 3960 BTUs/hr

Definition - 1.08 is the product of the specific heat (0.24 BTU x Air Density x minutes in an hour (60)

# HVAC Sizing

Air leakage / ventilation heat loss

$\text{btu/hr} = \text{CFM} \times \text{temp. difference} \times 1.1$

$= 60 \times 50 \times 1.1 = 3300 \text{ BTUs/hr}$

Definition - 1.08 is the product of the specific heat (0.24 BTU × Air Density × minutes in an hour (60)


# Proper Manual J Calculations

- Numerous software packages exist
- All rely on proper data input and appropriate assumptions

Common Errors:

- Fudging design day conditions
- Using default values for air tightness, windows, insulation
- Using improper ventilation rates

***Don't tolerate oversizing, Manual J compliant programs have safety factors built in already***



# Impact of Improper Sizing

- Short cycling
- Poor humidity control
- Poor temperature control
- Noise
- Extra cost for equipment & duct work
- Possibly higher energy bills

## Project Information


For:

## Design Conditions

Location:		Indoor:		Heating	Cooling
Richmond International AP, VA, US		Indoor temperature (°F)		70	75
Elevation: 164 ft		Design TD (°F)		49	17
Latitude: 38°N		Relative humidity (%)		30	50
		Moisture difference (gr/lb)		20.3	41.3
Outdoor:		Heating	Cooling		
Drybulb (°F)		21	92		
Dailyrange (°F)		-	19 ( M )		
Wetbulb (°F)		-	75		
Wind speed (mph)		15.0	7.5		
		Infiltration:			
		Method		Simplified	
		Construction quality		Tight	
		Fireplaces		1 (Average)	

## Heating

Component	Btu/h°F	Btuh	% of load
Walls	3.9	9120	28.4
Glazing	16.2	6676	20.8
Doors	17.7	744	2.3
Ceilings	1.3	2194	6.8
Floors	2.3	3667	12.1
Infiltration	1.6	4094	12.8
Ducts		2438	7.6
Piping		0	0
Humidification		0	0
Ventilation		2959	9.2
Adjustments		0	0
Total		32091	100.0



## Cooling

Component	Btu/h°F	Btuh	% of load
Walls	2.2	4998	22.9
Glazing	19.8	8150	37.3
Doors	10.6	445	2.0
Ceilings	1.4	2359	10.8
Floors	0	0	0
Infiltration	0.2	566	2.6
Ducts		2190	10.0
Ventilation		1040	4.8
Internal gains		2120	9.7
Blower		0	0
Adjustments		0	0
Total		21868	100.0




Latent Cooling Load = 3551 Btuh  
Overall U-value = 0.074 Btu/h/ft²·°F

Data entries checked.

# An Example House

4-ROOF VENTS ON GARAGE  
 6-ROOF VENTS ON HOUSE  
 1-ROOF VENT ON 4-SEASON PORCH  
 1/2"X6" SOFT. NOT FOR 1 SOFT.  
 SOFT. AREA. SEE IN SUPPLY SHEET  
 REAR VIEW  
 LOCATE FLUKE  
 VENTS IN BACK OF HOUSE  
 (WHEN POSSIBLE)



REAR ELEVATION  
 SCALE: 1/4"=1'-0"

FRONT ELEVATION  
 SCALE: 1/4"=1'-0"

FLOOR AREA: 2275 SQ. FT. FINISH

NOTE: R-5 INTERIOR FOUNDATION INSULATION IS NOT REQUIRED BECAUSE THIS HOME AIR LEAKAGE RATE WILL NOT EXCEED 2.0 AIR EXCHANGES ON BLOWER DOOR TEST

- NOTE: SCALE & PLACE ALL EXTERIOR OPENINGS.
- NOTE: IF HOUSE NUMBERS TO BE DISPLAYED ON HOUSE, VERIFY WITH STREET ROUTING PROPERTY.
- NOTE: LOCATE FLUKE VENTS AT THE BACK OF HOUSE.
- NOTE: ANY AND ALL LANDSCAPING OR RETAINING WALLS PROPOSED, WILL BE DEVER'S RESPONSIBILITY.
- NOTE: ALL EXTERIOR DOORS TO HAVE MIN. 100 LBS. THRESHOLD UNDER DOOR TO SUPPORT WHEELCHAIR.

USE APPROX. THESE DIMENSIONS WHEN CHANGES ARE REQUIRED TO MEET LOCAL CODES. ALL CHANGES TO THIS PLAN SHALL BE APPROVED BY THE LOCAL BUILDING DEPARTMENT. THE USER SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS. THE USER SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS. THE USER SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS.

BUYER: \_\_\_\_\_ DATE: \_\_\_\_\_  
 BUYER: \_\_\_\_\_ DATE: \_\_\_\_\_  
 PLAN NUMBER: \_\_\_\_\_ SERIAL: \_\_\_\_\_

#2594

PLAN NO.	#2594
DATE	1-1-18
DRAWN BY	JAYSON & KRISTIN BABLER
CHECKED BY	JAYSON & KRISTIN BABLER
SCALE	AS SHOWN
SHEET NO.	1 OF 8

DESIGNED FOR: JAYSON & KRISTIN BABLER

NOTE: ALL DIMENSIONS ARE TO FACE UNLESS OTHERWISE NOTED. ALL DIMENSIONS ARE TO FACE UNLESS OTHERWISE NOTED. ALL DIMENSIONS ARE TO FACE UNLESS OTHERWISE NOTED.

# Example Design Decisions

Parameter	Actual	Traditional
Design Temp (W) Design Temp (S)	-15 °F 91 °F	Its cold here: -22 °F Its getting hotter: 97 °F
Indoor Design (W) Indoor Design (S)	70 °F 75 °F	People are picky: 72 °F 72 °F
Orientation	North Front	Worst Case - East Front
Windows	From NFRC label U=0.28, SHGC=0.28 Overhangs used	Default U=0.41, SHGC=0.32 Overhangs not used
Air tightness	Actual 2.0 ACH50	Default 7.0 ACH50
Insulation	R50 ceilings R25 walls R 15 foundation	R44 ceilings R19 walls R 10 foundation
Ventilation	ERV - 75 CFM	Exhaust fans - 75 CFM



**Project Summary**  
**Entire House**  
 Authority Air Designs, LLC.

Job: V505  
 Date: Feb 09, 2015  
 By: Joe Colburn  
 Plan: Beazer Homes

6608 W. 95th Place, Westminster, CO 80021-6422 Phone: (720) 354-8105 Email: Joe@AuthorityAir.com Web: www.AuthorityAir.com

**Project Information**

For: Justin Wilson, Construction Instruction  
 3259 Spruce St., Denver, CO 80238  
 Phone: (719) 337-4749  
 Web: www.ConstructionInstruction.com Email: Justin@ConstructionInstruction.com

Notes:

**Design Information**

Weather: Charleston Intl AP, SC, US

**Winter Design Conditions**

Outside db 30 °F  
 Inside db 70 °F  
 Design TD 40 °F

**Summer Design Conditions**

Outside db 92 °F  
 Inside db 75 °F  
 Design TD 17 °F  
 Daily range M  
 Relative humidity 50 %  
 Moisture difference 55 gr/lb

**Heating Summary**

Structure 23079 Btuh  
 Ducts 2899 Btuh  
 Central vent (0 cfm) 0 Btuh  
 Humidification 0 Btuh  
 Piping 0 Btuh  
 Equipment load 25977 Btuh

**Sensible Cooling Equipment Load Sizing**

Structure 22909 Btuh  
 Ducts 3398 Btuh  
 Central vent (0 cfm) 0 Btuh  
 Blower 0 Btuh  
 Use manufacturer's data n  
 Rate/swing multiplier 0.97  
 Equipment sensible load 25545 Btuh

**Infiltration**

Method Simplified  
 Construction quality Tight  
 Fireplaces 1 (Tight)

	Heating	Cooling
Area (ft²)	2615	2615
Volume (ft³)	23534	23534
Air changes/hour	0.15	0.08
Equiv. AVF (cfm)	88	72

**Latent Cooling Equipment Load Sizing**

Structure 3518 Btuh  
 Ducts 525 Btuh  
 Central vent (0 cfm) 0 Btuh  
 Equipment latent load 4042 Btuh  
 Equipment total load 29587 Btuh  
 Req. total capacity at 0.80 SHR 2.7 ton

**Heating Equipment Summary**

Make Goodman Mfg.  
 Trade GMVC9 Series  
 Model GMVC950704CX  
 AHRI ref 2002232

Efficiency 96.1 AFUE  
 Heating input 69000 Btuh  
 Heating output 67000 Btuh  
 Temperature rise 48 °F  
 Actual air flow 1275 cfm  
 Air flow factor 0.049 cfm/Btuh  
 Static pressure 0.80 in H2O  
 Space thermostat

**Cooling Equipment Summary**



Make Goodman Mfg.  
 Trade GSX 13 Series  
 Cond GSX160361F  
 Coil CAPF3642C6D  
 AHRI ref 5986876

Efficiency 12.0 EER, 14.5 SEER  
 Sensible cooling 27200 Btuh  
 Latent cooling 6800 Btuh  
 Total cooling 34000 Btuh  
 Actual air flow 1275 cfm  
 Air flow factor 0.048 cfm/Btuh  
 Static pressure 0.80 in H2O  
 Load sensible heat ratio 0.87

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.


# An Accurate Manual J

# Heating Loads- HP Home Versus Standard





# Cooling Loads- HP Home Versus Standard


Cooling - Sensible + Latent Loads





ENERGY STAR HOME

TRADITIONAL DATA ENTRY





<b>ENERGY PERFORMANCE RATINGS</b>	
U-Factor (U.S./I-P) <b>0.30</b>	Solar Heat Gain Coefficient <b>0.36</b>
<b>ADDITIONAL PERFORMANCE RATINGS</b>	
Visible Transmittance <b>0.59</b>	—
<small>Manufacturer stipulates that these ratings conform to applicable NFRC procedures for determining whole product performance. NFRC ratings are determined for a fixed set of environmental conditions and a specific product size. Consult manufacturer's literature for other product performance information. www.nfrc.org</small>	
	ENERGY STAR® Qualified in All 50 States
Design Pressure (PSF) <b>DP 30</b>	 <b>F-C50 60" x 72"</b> <small>Tested to ANSIA/AAMA/NWDA 101/1.S.2-97 or NAFS-1</small>
<small>Meets or exceeds M.E.C., C.E.C., &amp; I.E.C.C. Air Infiltration Requirements WDMA Hallmark Certification Program Rev. 1/04 Part # 4780992</small>	



# The most 2 important numbers

- **SHGC** indicates how much incident solar radiation is admitted through a window as heat gain. The higher the number, the higher the solar gain.
- **U factor** describes the rate of heat transfer (i.e. how well the window insulates). The lower U factor, the better the window or door insulates.
- **SHGC and U factor** should be chosen carefully to optimize window performance in different climates.

**NOTE : SHGC affects 50%+ of most Heat Load calculations(Tonnage)**

ENERGY STAR® Certified in Highlighted Regions  
Certifié ENERGY STAR dans les régions en surbrillance

Canada



energy star  
ENERGY STAR  
energystar.gc.ca

■ = Zones 1 2 3

DO NOT REMOVE UNTIL FINAL INSPECTION/NE PAS RETIRER AVANT L'INSPECTION FINALE

Energy Performance Ratings Évaluation des propriétés énergétiques	
U-Factor Facteur U <b>1.10</b> W/m <sup>2</sup> ·K	U-value Coefficient de gain de chaleur totale <b>0.35</b>
Energy Rating Rendement énergétique <b>36</b>	Visual Transmittance Transmission visible <b>0.53</b>

**Window Company Ltd.**  
Triple X Operable Casement  
Vinyl frame, triple glaze, Low-e coating (e=0.322, 53, 55)  
Krypton/air filled (both cavities), Grills <= 12mm  
N10000-00000000-ES



Energy performance and visual transmittance ratings certified to CSA A440.2-14. Ratings are determined for a fixed set of environmental conditions and a specific product. Certification agency does not recommend or warrant product for any specific use.  
Les taux de performance énergétique et de transmission visible sont certifiés CSA A440.2-14. Les taux sont déterminés selon une série de conditions environnementales fixes et une série de produit particulière. L'agence de certification ne recommande ni ne garantit le produit aux fins d'utilisation particulières.

# WHY DUCT SIZING IS INCREASINGLY DRIVEN BY COOLING LOADS...EVEN IN THE NORTH!

- Fastest growing peak load
- Most costly comfort investment in any home
- Trickle down effect: HIGH SHGC WINDOWS = Increasing cooling loads = larger Duct sizing and air handler(furnace blower motor)

Single biggest factor  
in cooling loads:  
**WINDOWS!(SHGC)**



# Windows Solar Gain(SHGC) and Air Conditioning

## Window Case Study

- **Standard Clear Double Glazed**
- SHGC = .68
- **4.0 Ton AC Unit**
  
- **Double Glazed Low-e, Low SHGC**
- SHGC = .32
- **2.5 Ton AC Unit....1.5 Ton reduction!**



# SHGC AND COOLING LOADS

## Amount of Glass in New Homes : More or Less?


**2000 or before: 8 to 10%...**

**2010 to 2016: 12% to 17%....**

**2016 New product showing: 17% to 25%+**



Tread cautiously with higher SHGC. Comfort and Energy implications



# HOW MUCH HEAT/COOLING FOR A LOW LOAD ZERH? (1800 SFT)

HOME TYPE	Load
EXISTING HOME	<b>70,000 Heat</b> <b>36,000 Cool</b>
2012-2015 IECC BUILT HOME	<b>36,000</b> <b>24,000</b>
ZERH	<b>26,000</b> <b>18,500</b>

# Provide your Contractor with Good Information

- Insulation levels
  - Wall and attic insulation levels
  - Foundation insulation
- Window data - use NFRC ratings
  - Solar heat gain coefficients
  - U values
- House Air leakage - (this is often the single biggest variable)
  - Provide blower door test values

# Approved Software Guides Better Inputs

The screenshot displays the Right-Suite Universal 2017 software interface. The main window title is "Right-Suite® Universal 2017 - [Project1.rup: C:\Program Files\Wrightsoft HVAC\RSU.NavBar\Welcome to WSFRSU.htm]". The menu bar includes File, Edit, View, Show, Drawing, Proposal, Options, Window, Library, and Help. On the left, there is a sidebar with a "ci" logo and a "Project wizard" section containing numbered steps: 1 File, 2 Project Info, 3 Design Conditions, 4 Building, 5 System Type, 6 Distribution, 7 Reports, and 8 Finished. Below these are buttons for Draw, Multizone tree, Zone information, Load meter, Equipment, Duct, and Print preview. The main workspace shows a "Project Wizard" dialog box titled "Building Description".

**Project Wizard**

*Building Description*

The materials used in construction of the property have a significant effect on the cooling and heating loads. Entering correct values will help the software determine the correct load factors and thus produce accurate equipment sizing and running cost estimates.

**Please select appropriate building materials for the following**

Building type	2 level above grade- walk out	▼	...
Building materials	Basement - Finished Insulated	▼	...
Load preferences	Conditioned Space	▼	...
Tightness	Tight	▼	
Number of above grade stories	2	▼	
Number of fireplaces	1		
Fireplace quality	Tight	▼	

To select a pre-defined condition use the pulldown and select from the available choices.  
Pressing the [...] button will display the existing conditions and allow selection or creation of new, user created, choices.

< Back   Next >   Cancel   Help

At the bottom of the software interface, the status bar shows "Done", a green status indicator, "Entire House/0 zones", "0 zones", "0 rooms", "M38", and the date/time "04/20/16 02:19PM".

# Approved Software Guides Better Inputs

Right-Suite® Universal 2017 - [Test House EEBA HVAC, 4-20-16: Right-Draw®]

File Edit View Show Drawing Proposal Options Window Library Help

Library bu  
Attic ceili  
Bg floor.

ci

ject wizard  
w  
timize tree  
e information  
d meter  
ipment  
t  
at preview

Design  
Presentation  
Manage Sales  
Setup

Design

Help, press F1

### Constructions for Test House EEBA HVAC, 4-20-16 <none>

Select from library (none)

Description 2 glazing, clr outr, air gas, vnl frm mat, clr innr, 1/4" gap, 1/4" thk

Use Custom values

Custom

Glazing type Clear

Number of glazings (not including storm window) 1

NFRC rated  Has storm window

	Without storm window	With storm window	
U-value	0.570	0.570	Btuh/ft <sup>2</sup> ·°F
SHGC	0.56	0.56	

Results

SHGC w/o storm = 0.56  
U-val w/o storm = 0.570  
MJ8 Code = 2 glazing, clr outr, air  
MJ8 SHGC w/o storm = 0.56  
MJ8 U-val w/o storm = 0.570

Picture Not Available

OK Cancel Help

Level 3 Building  
Level 2 Building  
Level 1 Building

One sheet at a time

Entire House/0 zones 0 zones 0 rooms MJ8 04/20/16 02:21PM 0' x 0' 150'0" x 150'0"



**Project Information**

For: Justin Wilson, Construction Instruction  
 3259 Spruce St., Denver, CO 80238  
 Phone: (719) 337-4749  
 Web: www.ConstructionInstruction.com Email: Justin@ConstructionInstruction.com

**Design Conditions**

<b>Location:</b> Charleston Intl AP, SC, US Elevation: 49 ft Latitude: 33°N	<b>Indoor:</b> Indoor temperature (°F) 70 Design TD (°F) 40 Relative humidity (%) 50 Moisture difference (gr/lb) 35.4	<b>Heating</b> 70 40 50 35.4	<b>Cooling</b> 75 17 50 55.5
<b>Outdoor:</b> Dry bulb (°F) 30 Daily range (°F) - Wet bulb (°F) - Wind speed (mph) 15.0	<b>Heating</b> 30 - - 15.0	<b>Cooling</b> 92 16 ( M ) 78 7.5	<b>Infiltration:</b> Method Simplified Construction quality Tight Fireplaces 1 (Tight)

You can check the numbers against the detailed Heat Loss / Gain Report

Check them against your HERs raters reports too

Construction descriptions	Or	Area ft²	U-value Btu/ft²·h·°F	Insul R ft²·h/Btu	Htg HTM Btu/h·°F	Loss Btu/h	Cig HTM Btu/h·°F	Gain Btu/h
<b>Walls</b>								
STD - Basement Wall - R-13 - Framed: 8" Below Grade Concrete Wall, 2"x4" Walls, R-13 Cavity Insulation, 1/2" Gypsum Board Finish	n	123	0.057	13.0	0	0	0	0
	e	97	0.057	13.0	0	0	0	0
	s	143	0.057	13.0	0	0	0	0
	w	97	0.057	13.0	0	0	0	0
	all	460	0.057	13.0	0	0	0	0
STD - Frame - R-13S: Stucco Ext, 1/2" Wood Shth, 2"x 4" Frm Wall, R-13 Cavity Insulation, 1/2" Gypsum Board	n	402	0.092	13.0	3.66	1479	2.35	943
	ne	17	0.092	13.0	3.66	63	2.35	40
	e	861	0.092	13.0	3.66	3168	2.35	2020
	s	405	0.092	13.0	3.66	1491	2.35	951
	w	840	0.092	13.0	3.66	3092	2.35	1971
	nw	17	0.092	13.0	3.66	64	2.35	41
	all	2542	0.092	13.0	3.66	9358	2.35	5965
<b>Partitions</b> (none)								
<b>Windows</b>								
U-32 SHGC-32: U-32 SHGC-32 - Windows; NFRC rated (SHGC=0.32); 8 ft head ht	n	96	0.320	0	12.6	1260	12.0	1184
	ne	12	0.320	0	12.6	154	26.3	316
	e	110	0.320	0	12.6	1403	36.1	3957
	s	114	0.320	0	12.6	1455	15.7	1781
	w	71	0.320	0	12.6	914	36.1	2578
	nw	12	0.320	0	12.6	154	26.3	316
	all	417	0.320	0	12.6	5339	24.3	10133
U-32 SHGC-32 GD: U-32 SHGC-32 - Glass Door; NFRC rated (SHGC=0.32); 8 ft head ht	s	20	0.320	0	12.6	257	15.7	315
	w	18	0.320	0	12.6	229	36.1	645
	all	38	0.320	0	12.6	486	25.3	960
U-32 SHGC-32: U-32 SHGC-32 - Windows; NFRC rated (SHGC=0.32); 6 ft overhang (1 ft window ht, 0 ft sep.); 8 ft head ht	w	3	0.320	0	12.6	38	12.0	36
U-32 SHGC-32: U-32 SHGC-32 - Windows; NFRC rated (SHGC=0.32); 6 ft overhang (6 ft window ht, 0 ft sep.); 8 ft head ht	w	18	0.320	0	12.6	230	16.4	295





**Project Information**


For: Justin Wilson, Construction Instruction  
 3259 Spruce St., Denver, CO 80238  
 Phone: (719) 337-4749  
 Web: www.ConstructionInstruction.com Email: Justin@ConstructionInstruction.com

**Design Conditions**

<b>Location:</b>		<b>Indoor:</b>		<b>Heating</b>	<b>Cooling</b>
Charleston Intl AP, SC, US		Indoor temperature (°F)		70	75
Elevation: 49 ft		Design TD (°F)		40	17
Latitude: 33°N		Relative humidity (%)		50	50
<b>Outdoor:</b>		Moisture difference (gr/lb)		35.4	55.5
	<b>Heating</b>	<b>Cooling</b>	<b>Infiltration:</b>		
Dry bulb (°F)	30	92	Method		
Daily range (°F)	-	16 ( M )	Construction quality		
Wet bulb (°F)	-	78	Fireplaces		
Wind speed (mph)	15.0	7.5	Simplified		
			Tight		
			1 (Tight)		


**Heating**

Component	Btuh/ft²	Btuh	% of load
Walls	3.1	9358	36.0
Glazing	12.8	6094	23.5
Doors	4.0	161	0.6
Ceilings	1.1	1572	6.1
Floors	1.3	2044	7.9
Infiltration	1.2	3851	14.8
Ducts		2899	11.2
Piping		0	0
Humidification		0	0
Ventilation		0	0
Adjustments		0	0
<b>Total</b>		<b>25977</b>	<b>100.0</b>



**Cooling**

Component	Btuh/ft²	Btuh	% of load
Walls	2.0	5965	22.7
Glazing	24.0	11424	43.4
Doors	3.0	123	0.5
Ceilings	1.4	2123	8.1
Floors	0	0	0
Infiltration	0.4	1355	5.2
Ducts		3398	12.9
Ventilation		0	0
Internal gains		1920	7.3
Blower		0	0
Adjustments		0	0
<b>Total</b>		<b>26308</b>	<b>100.0</b>



Latent Cooling Load = 4042 Btuh  
 Overall U-value = 0.078 Btuh/ft²-°F

Data entries checked

Results can help you make better decisions

2) Select the right equipment



ACCA Equipment Selection



# Good System Selection

Heating and cooling systems come in specific sizes

(2, 2.5, 3 ton, or 45, 70, 90 Thousand BTUs for example)

- For heating it is acceptable to select a system that is within 110% -125% of the design load - slightly oversized
- For cooling choose a system that is between 90% - 110% of design load
- Other issues:
  - Equipment location (garage, attic, crawl...)
  - Blower type (ECM, PSC, HV...)
  - Filtration needs

# Good System Selection

- Use manufacturer's technical manuals to match:
  - Required heat output
  - Required cooling output
    - Sensible & latent (moisture) loads
  - Fan / airflow delivery capacity and static pressure

**\*UH2C100A9V4V FURNACE COOLING AIRFLOW (CFM) AND POWER (WATTS) VS. EXTERNAL STATIC PRESSURE WITH FILTER**

OUTDOOR UNIT SIZE (TONS)	AIRFLOW SETTING	DIP SWITCH SETTING					EXTERNAL STATIC PRESSURE				
		SW 1	SW 2	SW 3	SW 4		0.1	0.3	0.5	0.7	0.9
2.5	LOW (350 CFM/TON)	ON	ON	OFF	ON	CFM WATTS	808 75	824 125	840 170	835 210	830 250
	NORMAL (400 CFM/TON)	ON	ON	OFF	OFF	CFM WATTS	938 100	963 160	959 205	964 255	975 310
	HIGH (450 CFM/TON)	ON	ON	ON	OFF	CFM WATTS	1058 150	1100 200	1121 265	1136 330	1142 395
3.0	LOW (350 CFM/TON)	OFF	ON	OFF	ON	CFM WATTS	1004 120	1010 175	1027 230	1044 285	1050 345
	NORMAL (400 CFM/TON)	OFF	ON	OFF	OFF	CFM WATTS	1141 170	1190 245	1214 310	1229 380	1234 450
	HIGH (450 CFM/TON)	OFF	ON	ON	OFF	CFM WATTS	1336 250	1375 330	1387 410	1388 480	1384 545
3.5	LOW (350 CFM/TON)	ON	OFF	OFF	ON	CFM WATTS	1153 180	1206 250	1230 320	1239 395	1244 460
	NORMAL (400 CFM/TON)	ON	OFF	OFF	OFF	CFM WATTS	1390 285	1418 465	1439 445	1441 515	1373 540
	HIGH (450 CFM/TON)	ON	OFF	ON	OFF	CFM WATTS	1575 400	1606 495	1632 590	1596 645	1445 590
4.0	LOW (350 CFM/TON)	OFF	OFF	OFF	ON	CFM WATTS	1388 290	1423 360	1444 440	1444 515	1390 540
	NORMAL (400 CFM/TON)	OFF	OFF	OFF	OFF	CFM WATTS	1610 415	1641 515	1666 635	1607 650	1449 595
	HIGH (450 CFM/TON)	OFF	OFF	ON	OFF	CFM WATTS	1847 630	1863 735	1816 780	1687 720	1532 665

NOTES: \*First letter may be "A" or "T"

1. At Continuous fan setting: Heating or Cooling airflows are approximately 50% of selected cooling value.

2. LOW airflow (350 cfm/ton) is COMFORT & HUMID CLIMATE setting;

NORMAL airflow (400 cfm/ton) is typical setting;

HIGH airflow (450 cfm/ton) is DRY CLIMATE setting.

**Use real fan specs.**


# Preferred furnace choices

68

- Sealed combustion chamber
- Venting system decoupled from house pressures
- Efficiencies of 90%+
- High efficiency blower motors - ECM
- Two/multi stage heating



# Always Choose Direct Vent



# LOW LOAD HOMES AND EQUIPMENT SELECTION

70

SINGLE STAGE

VS

2 STAGE

VS

FULL MODULATION

What's the difference???



Three-storey, town	Two-storey, detached	Single-storey, detached	Two-storey stacked back-to-back town
 <p>Image used with builder's permission</p>	 <p>Image used with builder's permission</p>	 <p>Image used with builder's permission</p>	 <p>Image used with builder's permission</p>
<p><b>Description:</b></p> <ul style="list-style-type: none"> <li>• 1,600 sf on 3 floors plus basement</li> <li>• Front facing E (highest cooling)</li> <li>• Energy Star certified</li> </ul>	<p><b>Description:</b></p> <ul style="list-style-type: none"> <li>• 1,400 sf on 2 floors plus basement</li> <li>• Front facing W (highest cooling)</li> <li>• Energy Star certified</li> </ul>	<p><b>Description:</b></p> <ul style="list-style-type: none"> <li>• 1,300 sf bungalow plus basement</li> <li>• Front facing NW (highest cooling)</li> <li>• Energy Star certified</li> </ul>	<p><b>Description:</b></p> <ul style="list-style-type: none"> <li>• 1,000 sf on 2 floors</li> <li>• Front facing SW (highest cooling); Units A &amp; B share an entrance</li> <li>• Energy Star certified</li> </ul>
<p><b>Design Loads:</b> (for mid unit)</p>	<p><b>Design Loads:</b></p>	<p><b>Design Loads:</b></p>	<p><b>Design Loads:</b> (for upper-mid unit)</p>
<p><b>Greater Toronto Area, ON</b>                      DHL: 15,786 Btu/h                      DHG: 19,192 Btu/h</p>	<p><b>Greater Toronto Area, ON</b>                      DHL: 16,547 Btu/h                      DHG: 18,556 Btu/h</p>	<p><b>Greater Toronto Area, ON</b>                      DHL: 20,335 Btu/h                      DHG: 19,354 Btu/h</p>	<p><b>Greater Toronto Area, ON</b>                      DHL: 16,901 Btu/h                      DHG: 13,850 Btu/h</p>
<p><b>Ottawa, ON</b>                      DHL: 17,721 Btu/h</p>	<p><b>Ottawa, ON</b>                      DHL: 18,573 Btu/h</p>	<p><b>Ottawa, ON</b>                      DHL: 22,862 Btu/h</p>	<p><b>Ottawa, ON</b>                      DHL: 7,984 Btu/h</p>
<p><b>Calgary, AB</b>                      DHL: 19,817 Btu/h                      DHG: 18,118 Btu/h</p>	<p><b>Calgary, AB</b>                      DHL: 20,738 Btu/h                      DHG: 17,375 Btu/h</p>	<p><b>Calgary, AB</b>                      DHL: 25,601                      DHG: 18,851 Btu/h</p>	<p><b>Calgary, AB</b>                      DHL: 8,775 Btu/h                      DHG: 14,468 Btu/h</p>
<p><b>Saskatoon, SK</b>                      DHL: 21,991 Btu/h                      DHG: 18,822 Btu/h</p>	<p><b>Saskatoon, SK</b>                      DHL: 22,879 Btu/h                      DHG: 18,169 Btu/h</p>	<p><b>Saskatoon, SK</b>                      DHL: 28,249 Btu/h                      DHG: 19,899 Btu/h</p>	<p><b>Saskatoon, SK</b>                      DHL: 9,779 Btu/h                      DHG: 14,841 Btu/h</p>



# A STUDY IN EQUIPMENT SELECTION FOR LOW LOAD HOMES




Figure 21: Runtime Duration Curves for Single-Stage Equipment

# A STUDY IN EQUIPMENT SELECTION FOR LOW LOAD HOMES

## Heating System Runtime Duration Curves for Different Sizes of Two-stage Equipment




Figure 22: Runtime Duration Curves for Two-Stage Equipment

# A STUDY IN EQUIPMENT SELECTION FOR LOW LOAD HOMES

Table 8: Median and Coldest-day Hourly Runtimes for Single-Stage

Parameter	A-size (120% of F280)	B-size (170% of F280)	C-size (250% of F280)
<b>Median Runtimes</b>	17 minutes per hour	12 minutes per hour	8 minutes per hour
<b>Coldest 5% ON-times</b>	39 minutes per hour	27 minutes per hour	18 minutes per hour
<b>Coldest 5% OFF-times</b>	21 minutes per hour	33 minutes per hours	42 minutes per hour

SINGLE  
STAGE

Table 9: Median and Coldest-day Hourly Runtimes for Two-Stage

Parameter	A-size (120% of F280)	B-size (170% of F280)	C-size (250% of F280)
<b>Median Runtimes</b>	29 minutes per hour	20 minutes per hour	13 minutes per hour
<b>Coldest 5% ON-times</b>	54 minutes per hour	45 minutes per hour	31 minutes per hour
<b>Coldest 5% OFF-times</b>	6 minutes per hour	15 minutes per hours	29 minutes per hour

TWO  
STAGE

Table 10: Median and Coldest-day Hourly Runtimes for Modulating Heating Systems

Parameter	A-size (120% of F280)	B-size (170% of F280)	C-size (250% of F280)
<b>Median Runtimes</b>	39 minutes per hour	30 minutes per hour	20 minutes per hour
<b>Coldest 5% ON-times</b>	57 minutes per hour	53 minutes per hour	46 minutes per hour
<b>Coldest 5% OFF-times</b>	3 minutes per hour	7 minutes per hours	14 minutes per hour

MODULATING

# Preferred AC choices

75

- Outdoor condenser matched to indoor coil
- SEER ratings of 14+
- High efficiency blower motors - ECM
- Two - stage cooling
- Dehumidification cycles
- Inverter for simple connection to solar




# New Realities in HVAC Design & Performance

## **High Performance homes need more efficient motors!**


- Capable of meeting small loads, part loads and full loads!
- Use 1/5 of original PSC motor types.
- Run efficiently at a variety of speeds (Modulation)
- Equipment lasts longer
- Enables balanced temperatures throughout home
- Enhances Ventilation “Effectiveness”



# ECM Product Features: Efficiency




# ECM Product Features: Constant Airflow



# What about Heat Pumps?

- Is it the first thing to do?
- Reliance on electric grid
- Can do Ground, Water or Air
- High Performance homes help reduce capital cost



# Energy Efficiency

- Heat pumps are hard to overlook
- Low ambient temperature units: COPs of 2 to 4
- Be mindful of HSPF rating points and operating conditions – cold weather:
- Zone 5+ + 8.6 HSPF+
- Dual Fuel /Auxillary back up as gas vs electric.



# HVAC NET ZERO HOME LESSONS LEARNED: EQUIPMENT

- Enables “smart” use of Electrical or Gas
- Balance point can be either Operational OR Economic
- Provides resilience



# HVAC NET ZERO LESSONS LEARNED:

Low loads change the game.  
Low ambient heat pump study



	Manufacturer	EnerGuide	Test	Season
<b>ASHP</b>				
Seasonal Energy Efficiency Ratio (SEER)	16	$\geq 14$	18	Cooling
Coefficient of Performance (COP)	2.75	2.05	3.23	Heating
<b>GSHP</b>				
Seasonal Energy Efficiency Ratio (SEER)	12.9	$\geq 14.1$	19.7	Cooling
Coefficient of Performance (COP)	3.0	$\geq 3.3$	3.44	Heating

# Select Heat Pumps for both Cooling & Heating Capacity

## MUZ-HM24NA2

Outdoor unit model			MUZ-HM24NA2
Capacity Rated (Minimum~Maximum)	Cooling #1	Btu/h	22,500 (5,800 ~ 22,500)
	Heating 47 #1	Btu/h	26,000 (5,400 ~ 26,000)
Capacity Rated (Maximum)	Heating 17 #2	Btu/h	18,500 (18,500)
Power consumption Rated (Minimum~Maximum)	Cooling #1	W	2,575 (275 ~ 2,575)
	Heating 47 #1	W	2,445 (265 ~ 2,445)
Power consumption Rated (Maximum)	Heating 17 #2	W	2,245 (2,245)
EER #1 [SEER] #3	Cooling		8.6 [18.0]
HSPF IV #4	Heating		8.5
COP	Heating #1		3.05
Power factor	Cooling (208/230)	%	99/99
	Heating (208/230)	%	99/99

New Low Temperature Heat Pumps can be very effective  
 - when properly sized and selected

Cooling Capacity Btu/h	EER	SEER	Heating Capacity Btu/h		COP	HSPF
			47°F	17°F		
18,000	12.50	18.0	22,000	13,900	3.44	9.3
18,000	12.10	16.0	22,000	13,900	3.52	9.0
18,000	12.30	17.0	22,000	13,900	3.48	9.2
18,000	12.50	18.0	22,000	13,900	3.67	9.0
22,000	12.50	18.0	24,000	14,100	4.04	9.5
22,000	10.60	15.5	24,000	14,100	3.42	9.0
22,000	11.55	16.8	24,000	14,100	3.74	9.3
35,200	8.80	16.0	36,400	22,000	3.56	9.4
33,800	8.10	14.5	36,400	21,200	3.08	8.7
34,400	8.45	15.3	36,400	21,600	3.32	9.1

# Select Heat Pump Capacity based on Outside Temperature

Outdoor Temp (°FWB)	Capacity (Btu/h)	Input (Watts)	COP
60	45,980	3,811	3.5
55	41,040	3,650	3.3
50	39,710	3,521	3.3
45	38,608	3,295	3.4
40	38,000	3,230	3.4
35	38,000	4,038	2.8
30	38,000	4,684	2.4
25	38,000	5,168	2.2
20	38,000	5,491	2.0
15	38,000	5,749	1.9
10	38,000	5,911	1.9
5	38,000	6,040	1.8
0	35,720	6,105	1.7
-5	33,820	6,072	1.6
-10	31,920	6,137	1.5
-15	29,640	6,202	1.4
-20	27,360	6,234	1.3
-25	25,080	6,266	1.2
-30	22,800	6,299	1.1
-35	20,520	6,331	0.9

\* Above numbers are approximated

# Example of a different strategy

- Ductless opportunities




- Provides zoning
- Can target specific high load areas

# Mini-Split Systems - with Low Temp. capabilities



- In very high performance homes, it could provide all heating & cooling needs


3) Design the ducts correctly



ACCA Duct Design



Manual D provides a duct sizing schedule to deliver the air to the space intended




Manual D provides a duct sizing schedule to deliver the air to the space intended

Name	Design (Btuh)	Htg (cfm)	Clg (cfm)	Design FR	Diam (in)	Rect Size (in)	Duct Matl	Actual Ln (ft)	Ftg.Eqv Ln (ft)	Trunk
Opt Bedroom	c 830	46	50	0.429	4	0x0	ShMt	19.8	60.0	
Opt Bedroom-A	c 830	46	50	0.205	4	0x0	ShMt	27.3	140.0	st1
Great Room	c 2395	121	144	0.242	6	0x0	ShMt	21.8	120.0	st2
Master Bedroom-A	c 1679	72	101	0.092	6	0x0	ShMt	60.6	310.0	st3
Master Bedroom	c 1679	72	101	0.123	6	0x0	ShMt	29.5	250.0	st23
Master Bath	h 2000	61	50	0.134	5	0x0	ShMt	35.4	220.0	st21
Bath	h 531	16	13	0.102	4	0x0	ShMt	32.6	305.0	st18
Bedroom 2	c 1854	93	111	0.087	6	0x0	ShMt	74.6	320.0	st16
Stairs/Hall Up	h 1323	41	35	0.085	4	0x0	ShMt	40.9	360.0	st14
Bedroom 3	c 1977	88	119	0.094	6	0x0	ShMt	50.3	315.0	st5
WIC	h 392	12	9	0.138	4	0x0	ShMt	28.3	220.0	st20
Dining Room	c 891	45	54	0.130	4	0x0	ShMt	17.9	245.0	st6
Living Room	h 3264	100	94	0.102	6	0x0	ShMt	55.6	280.0	st10
Opt Bedroom 2	h 2271	70	63	0.098	5	0x0	ShMt	55.8	295.0	st12
Powder	h 641	20	19	0.102	4	0x0	ShMt	36.1	300.0	st7
Foyer/Stairs	c 890	53	53	0.084	5	0x0	ShMt	42.8	365.0	st8
Opt Bath	h 330	10	1	0.129	4	0x0	ShMt	30.3	235.0	st17
Opt Rec Room	h 1945	60	32	0.143	4	0x0	ShMt	9.6	230.0	st19
Kitchen	h 2345	72	40	0.293	4	0x0	ShMt	7.0	110.0	st2
Opt Rec Room-A	h 1945	60	32	0.128	5	0x0	ShMt	23.7	245.0	st6
Laundry	h 1362	42	29	0.103	4	0x0	ShMt	32.2	300.0	st7

# Example- Duct Design for Bedroom #3

		Design BTU	Design CFM	Design Friction	Dia.
Bed-3	Heat	1700	31	0.1	4"
	Cool	1366	49	0.1	5"



The air required is calculated by the formula:

$$\text{CFM} = \frac{\text{BTU/hr}}{1.1 \times \text{Temp. rise across furnace}}$$

# Heat & Air Distribution

BTU/hr Carrying Capacity

<b>Duct size</b>	<b>Airflow CFM</b>	<b>25 °F Cooling</b>	<b>45 °F Heating</b>	<b>55 °F Heating</b>
<b>4"</b>	30-40	800 -1100	1485 -1980	1815 - 2420
<b>5"</b>	50-60	1300 -1650	<b>2375 - 3960</b>	3025 - 3630
<b>6"</b>	90-110	2475 -3025	4455 - 5445	5445 - 6710

# ZERH = LOW LOAD HOMES

## DISTRIBUTION SIZING AND SELECTION

	<b>1990 Code</b>	<b>IECC 2012</b>	<b>ZERH</b>
<b>Load</b>	70,000 BTUs 3.0 tons	36,000 BTUs 2.0 tons	26,000 BTUs 1.5 tons
<b>Air Flow</b>	1200 CFM	750 CFM	600 CFM
<b>Duct sizes</b>			
• <b>Mains</b>	8" x 28"	8" x 18"	8" x 12"
• <b>Branch</b>	5" - 6"	5"	3" - 4"

# Distribution Systems



- HVAC contractor must use the heat loss/gain calculations to properly size duct work
  - It is critical to consider the entire system and process.
    - Layout & location of distribution system
    - Materials used - flexible duct or sheet metal, insulated or non-insulated
    - Impact on pressurization of rooms or spaces
    - Effective occupant comfort control

# HVAC by Design

- Properly size system
- Optimize duct layout

Traditional

Advanced



Ducts & equipment  
in conditioned  
space

A closet & dropped  
ceiling

Use direct vent  
equipment





Ducts in conditioned space will be cooler in summer, warmer in winter

# Conditioned attics are an option



It can raise the  
value of a home

Place the ducts in conditioned space

A dropped ceiling in the hallway can be effective



Ducts are now properly insulated and any duct leakage is to the interior





Properly sized and located grilles “throw”  
air to the perimeter windows and walls






Open web floor joist systems

# Layout your floors to accommodate duct




# Buried Ducts are an Option




# Seal Ducts

Mastic with a brush is quickest & best



# Sealing Ducts Matters!!!



- Getting air where you need it
- Allowing balancing & seasonal adjustment to work
- Empowers zoning to work



# Low Load Homes suffer from lack of air flow-THROW and MIXING! (Not lack of Returns)

Standard register

Small diffuser




HEATING

350 FPM

S=SUPPLY R=RETURN

FLOOR REGISTERS AT PERIMETER




COOLING


350 FPM

S=SUPPLY R=RETURN



FLOOR REGISTERS AT PERIMETER



# Choose Proper Diffusers with Velocity and "Throw" in Mind



STAGNANT IS ONLY IN THIS AREA DUE TO COANDA EFFECT OF AIR ON CEILING



# Zoning is becoming (almost) a requirement in some low load home designs

- Matching seasonal load adjustments
- Example – basements
- Accurate delivery of part loads in 3 story higher density townhome designs
- Making best use of equipment capacity
- Efficiency and cost savings? Cooling = 20% savings - +




# Ducted Returns will become expected





- A good choice is to hard duct returns...strategically to a centralized location



# Return Air Paths







A single return requires transfer grilles to provide a return path, and avoid pressurizing bedrooms



Note: not an IECC requirement

